

EC-TYPE EXAMINATION CERTIFICATE

Application of: Council Directive 96/98/EC of 20 December 1996 on Marine Equipment as amended by directive 2014/93/EU, issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Directorate. This Certificate is issued by DNV GL AS under the authority of the Government of the Kingdom of Norway.

This is to certify:

That the Fire Doors

with type designation(s)
COSMO A-60TVHD-R

Issued to


Cosmo Co., Ltd.
Gyeongsangnam-do Korea, Republic of Korea

is found to comply with the requirements in the following Regulations/Standards:

Annex A.1, item No. A.1/3.16 and Annex B, Module B in the Directive. SOLAS 74 as amended, Regulation II-2/and IMO 2010 FTP Code

Further details of the equipment and conditions for certification are given overleaf.

Høvik, 2015-09-02
for **DNV GL AS**



This Certificate is valid until
2020-09-01

Notified Body No.: **0575**

Vidar Dolonen
Head of Department

DNV GL local office:
Gimhae MC & FIS

Synnøve Bolstad Eri
Surveyor

Product description

"COSMO A-60TVHD-R"

is a double leaf hinged door. Each door leaf consists of an insulation core of mineral wool, density 280 kg/m³ (manufactured by KCC Corporation), faced on both sides with 0.6 mm thick steel panels. Adhesive is applied between the insulation and the steel panels. The upper part of the door leaf incorporates two horizontal stiffeners. The top of the door leaf, 100 mm space on each side, is internally reinforced with 2 mm thick steel plate and the lower part is internally reinforced with a 1.5 mm thick steel stiffener. Along the edges, the door leaf is fitted with a 0.6 mm thick edge cover.

Total door leaf thickness is 52 mm.

Each door leaf is connected to the frame by 3 reinforced hinges. The door frame is made from 1.5 mm thick steel sheets, internally insulated with mineral wool (the same as above). The door frame may be bolted by M5x25L bolts (spaced 200-300 mm apart) or welded to the bulkhead.

The doors may be fitted with:

- Window between the two stiffeners in the upper part of the door leaf, type designation "CONTRAFLAM A60" (manufactured by Vetrotech Saint-Gobain). Thickness: 27 mm.
- Hose port in lower corner of the door leaf (opposite to hinge side), 150 mm x 150 mm (w x h).

For further details see Type Examination documentation below.

Application/Limitation

The door is approved for installation in steel bulkheads of class A-60. Installation of the door in bulkheads made of other materials (aluminium, FRP, etc.) are subject to case-by-case approval.

Max. size of door leaf:	1017 mm x 2105 mm (w x h)
Max. clear opening door:	2000 mm x 2100 mm (w x h)
Max. clear opening window:	400 mm x 400 mm (w x h)

The insulation materials and adhesives used have to be approved according to the Marine Equipment Directive and bear the Mark of Conformity. This requirement may also be applicable for surface materials used, if required by relevant rules and regulations.

The door has been successfully tested with extended test period in compliance with IMO MSC.1/Circ. 1319.

The product is to be supplied with its manual for installation, use and maintenance.

Type Examination documentation

Test report No. AK2015-0196 dated 30 April 2015 from Fire Insurers Laboratories of Korea (FILK), Korea.

Drawing No. CD-FA60TVHDDR-0 (10 pages) dated 12 March 2015 from the manufacturer.

Tests carried out

Tested according to IMO 2010 FTP Code part 3.

Marking of product

The product is to be marked with name of manufacturer, type designation, fire-technical rating, MED Mark of Conformity and USCG approval number if relevant (see page 3).

Job Id: **344.1-004903-1**
Certificate No: **MEDB0000077**

Mark of Conformity

The manufacturer is allowed to affix the Mark of Conformity according to Article 11 in the Council Directive 96/98/EC on Marine Equipment and shall issue a Declaration of Conformity, only when the module D or E or F of Annex B in the same directive is fully complied with.

Module D: The quality system for production and testing shall be approved by the Notified Body.

Module E: The quality system for inspection and testing shall be approved by the Notified Body.

Module F: Compliance of the products to type as described in this EC Type-Examination Certificate must be verified by the Notified Body who also shall issue a Certificate of Conformity.

USCG Approval

An U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the "Agreement between the United States of America and the EEA EFTA states on the mutual recognition of Certificates of Conformity for Marine Equipment" signed 17 October 2005.

USCG approval limitations

The approval is limited to fire doors without windows and doors with total window area of 645 cm², or less, in each door leaf. For larger windows, USCG shall be contacted.