

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Application of: Council Directive 96/98/EC of 20 December 1996 on Marine Equipment as amended by directive (EU) 2015/559, issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV GL AS under the authority of the Government of the Kingdom of Norway.

This is to certify:

That the Penetrations through "A" class divisions: pipe, duct, trunk, etc penetrations

with type designation(s)
Blücher Cabin Drain

Issued to
Blücher Metal A/S
VILDBJERG, Denmark

is found to comply with the requirements in the following Regulations/Standards:
Annex A.1, item No. A.1/3.26b and Annex B, Module B in the Directive; SOLAS 74 as amended, Regulation II-2/9, IMO MSC/Circ.1276 and IMO 2010 FTP Code


Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2021-06-10**.

Issued at **Høvik** on **2016-07-06**

DNV GL local station:
Aalborg

Approval Engineer:
Piotr Orzechowski



Notified Body
No.: **0575**

for **DNV GL AS**

Vidar Dolonen
Head of Notified Body

Job Id: **344.1-000332-26**
Certificate No: **MEDB000016X**

Product description

"Blücher Cabin Drain"

system composed of a lower part, an upper part and a water trap. The lower part is welded to a deck. Insulation is required by using approved insulation (e.g. Paroc Wired Mat 100, 50 mm, density 100 kg/m³) according to drawing S-0430-300.

Application/Limitation

Approved for use as a marine drain system in class A-0 to A-60 deck. Other applications are subject to case-by-case approval.

The insulation material used has to be approved according to the Marine Equipment Directive and bear the Mark of Conformity.

Watertightness and gastightness is not covered in this certificate.

The penetration system is generally not to be used for penetrating boundaries of tanks.

Each product is to be supplied with its manual for installation and maintenance.

Type Examination documentation

Test reports Nos. PG12302 and PG 12303 dated 27 January 2011 from DBI, Denmark.

Drawing No. S-0430-300 from Blücher Metal A/S.

Tests carried out

Tested according to IMO FTPC Part 3 and in compliance with IMO 2010 FTP Code Ch. 8.

Marking of product

The product or packing is to be marked with name of manufacturer, type designation, fire-technical rating, MED Mark of Conformity and USCG approval number if applicable.