EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate No:
MEDB000018H

Application of: Council Directive 96/98/EC of 20 December 1996 on Marine Equipment (MED) as amended by directive (EU) 2015/559. This Certificate is issued by DNV GL SE based on the notification of the German Federal Ministry of Transport, Building and Urban Development.

This is to certify:

That the Surface materials and floor coverings with low flame-spread characteristics
with type designation(s)
High Pressure Laminate (HPL) decorative veneer
Issued to

Shanghai Hejiu Decoration Materials Co., Ltd.

Shanghai, China

is found to comply with the requirements in the following Regulations/Standards:
Annex A.1, item No. A.1/3.18a and Annex B, Module B in the Directive; SOLAS 74, Reg. II-2/3, II-2/5, II-2/6, II-2/9 & X/3, IMO MSC/Circ. 1120, 2000 HSC Code 7 and IMO 2010 FTP Code
Further details of the equipment and conditions for certification are given overleaf.
This Certificate is valid until **2021-07-25**.

Issued at **Hamburg** on **2016-07-26**

Notified Body
No.: **0098**

DNV GL local station:
Shanghai CMC
Approval Engineer:
Pavel Golyshev

for **DNV GL SE**

Sven Dudszus
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the "Agreement between the European Community and the United States of America on Mutual Recognition of Certificates of Conformity for Marine Equipment", signed February 27th, 2004.
The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Council Directive 96/98/EC, as amended.
This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV GL SE of any changes to the approved equipment.
Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Product description

High Pressure Laminate (HPL) decorative veneer.
Thickness 0.8 mm.

Application/Limitation

Approved for use as low flame spread material, not generating excessive quantities of neither smoke nor toxic products in fire.
Maximum gross calorific value shall be documented separately where applicable, ref. SOLAS Chapter II-2 Reg. 5.3.2.
Each product is to be supplied with its manual for application and maintenance.

Type Examination documentation

Test report No. FT09244 dated 24th of September 2009, issued by the Far East Fire Testing Centre (FEFTC), Shanghai, China

Tests carried out

Tested according to IMO 2010 FTP Code Part 5 and Annex 2 item 2.2 and in compliance with IMO 2010 FTP Code Ch.8.

Marking of product

The product or packing is to be marked with name of manufacturer, type designation, MED Mark of Conformity and USCG approval number if applicable.