DNV·GL

Certificate No:
MEDB00001GE

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV GL AS under the authority of the Government of the Kingdom of Norway.

This is to certify:

That the Penetrations through "A" class divisions: electric cable transits

with type designation(s)
A-0 PENESEAL PS-100A

Issued to
PnC TECH BUSAN CO., LTD.
Busan, Republic of Korea

is found to comply with the requirements in the following Regulations/Standards:
Regulation **(EU) 2015/559,**
Annex A.1, item No. A.1/3.26a and Annex B, Module B in the Directive; SOLAS 74 as amended, Regulation II-2/9, IMO MSC/Circ.1276 and IMO 2010 FTP Code

Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2022-01-10**.

Issued at **Høvik** on **2017-01-11**

DNV GL local station:
Busan

Approval Engineer:
Piotr Orzechowski

Notified Body
No.: **0575**

for **DNV GL AS**

Vidar Dolonen
Head of Notified Body

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Product description

"A-0 PENESEAL PS-100A"
Composed of a rectangular/circular 180 mm long steel sleeve welded to the bulkhead/deck and filled with Resins types "PS-A" & "PS-B" and Sealer "PS-S".

For bulkhead installation:
The sleeve is fitted symmetrically into the bulkhead and is filled with 140 mm Resin "PS-A and PS-B" and 20 mm Sealer "PS-S" at each end of the cable penetration.

For deck installation:
The sleeve is fitted unsymmetrically (130 mm on exposed side) into the deck. The sleeve is filled with 160 mm Resin "PS-A and PS-B" and 20 mm Sealer "PS-S" on the exposed side of the cable penetration.

The filling compound is made of two Resin types "PS-A" & "PS-B",mixed together before use. For penetration with lower filling rates additional Filler made of Resin types "PS-A" & "PS-B" is used for filling the empty space.
For rectangular penetrations two ø 50 mm filling holes are fitted in the sleeve for filling resin inside.

Spacer may necessary be installed between cable and between cable and transit to keep the minimum distance (at least 4mm).

For further details please see approved manufacturer's drawings PS-A0 DK and PS-A0 BH.

Application/Limitation

The penetration is approved for installation in steel bulkhead/deck of class A-0. Other applications are subject to case-by-case approval.

Restricted application for deck penetration - fire from Sealer side only.

Approved sizes:

Minimum size:	178 x 118 x 6 mm	(W x H x T)	with min/max filling rate:	3%/30%
	50A (ø60.5) x 3.65 mm	(D x T)	with min/max filling rate:	17%
	40A (ø48.6) x 3.25 mm	(D x T)	with min/max filling rate:	9%
Maximum size:	672 x 312 x 6 mm	(W x H x T)	with min/max filling rate:	3%/34%
	200A (ø216.3) x 5.85mm	(D x T)	with min/max filling rate:	3%/33%

Minimum distance between cables: 4 mm
Distance between cable and sleeve: 4 mm

The penetration system shall not be used for penetrating boundaries of tanks.

Each product is to be supplied with its manual for installation and maintenance.

Type Examination documentation

Test Report Nos.:

Tests carried out

Tested according to IMO 2010 FTP Code part 3.

Marking of product

The product or packing is to be marked with name and address of manufacturer, type designation, fire-technical rating, MED Mark of Conformity and USCG approval number if applicable (see first page).

Job Id:
Certificate No: **MEDB00001GE**

Additional application/information for Watertightness/gastightness (Not part of the Marine Equipment Directive requirement)

Product description

"A-0 PENESEAL PS-100A"
Composed of a rectangular/circular 180 mm long steel sleeve welded to the bulkhead/deck and filled with Resins types "PS-A" & "PS-B" and Sealer "PS-S".

For bulkhead installation:
The sleeve is fitted symmetrically into the bulkhead and is filled with 140 mm Resin "PS-A and PS-B" and 20 mm Sealer "PS-S" in each end of the cable penetration.

For deck installation:
The sleeve is fitted unsymmetrically (130 mm on exposed side) into the deck and is fixed 130 mm on exposed side of division. The sleeve is filled with 160 mm Resin "PS-A and PS-B" and 20 mm Sealer "PS-S" on the exposed side of the cable penetration.

The filling compound is made of two Resin types "PS-A" & "PS-B",mixed together before use. For penetration with lower filling rates additional Filler made of Resin types "PS-A" & "PS-B" is used for filling the empty space.
For rectangular penetrations two ø 50 mm filling holes are fitted in the sleeve for filling resin inside.

Spacer may necessary be installed between cable and between cable and transit to keep the minimum distance (at least 4mm).

For further details please see approved manufacturer's drawings PS-A0 DK and PS-A0 BH.

Application/Limitation

Approved for penetration in steel bulkheads or steel decks limited to a pressure of 2.5 bar watertightness (3.75 bar – tested pressure) and 1 bar gastightness (1.5 bar - tested pressure).

The penetration system is not to be used for penetrating boundaries of tanks.

Type Approval documentation

Test reports No. PnC-WT-01~08 and PnC-GT-01~08 dated 31 May 2016 from PnC Tech Busan Co., Ltd.

Tests carried out

Pressure tests with water and air according to Class Programme DNVGL-CP-0165, Edition Fabruray 2016.