

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV GL AS under the authority of the Government of the Kingdom of Norway.

This is to certify:**That the Non-combustible materials**

with type designation(s)

GLAVA VENTILASJONSPLATE

Issued to

Glava AS
ASKIM, Norway

is found to comply with the requirements in the following Regulations/Standards:

Regulation **(EU) 2017/306**,

item No. MED/3.13. SOLAS 74 as amended, Regulation II-2/3 II-2/5, II-2/9 & X/3, 2000 HSC Code 7 and IMO 2010 FTP Code

Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2022-07-12**.


Issued at **Høvik** on **2017-07-13**

DNV GL local station:

Oslo Maritime and CAP

Approval Engineer:

Synnøve Bolstad Eri



Notified Body
No.: **0575**

for **DNV GL AS**

Vidar Dolonen
Head of Notified Body



Job Id: **344.1-000909-42**
Certificate No: **MEDB000028V**

Product description

"GLAVA VENTILASJONSPLATE"

Consist of glass wool.

Nominal density (approx.): 35 kg/m³

Application/Limitation

Approved for use as non-combustible materials.

The product may be used as an integrated part of approved fire resisting divisions only when tested as such.

Each product is to be supplied with its manual for installation and use.

Type Examination documentation

Test reports No. 102010.10/03.107 dated 28 April 2003 from NBL, SINTEF, Trondheim, Norway.

Tests carried out

Tested according to IMO FTPC Part 1 and in compliance with IMO 2010 FTP Code Ch. 8.

Marking of product

The product or packing is to be marked with name and address of manufacturer, type designation, MED Mark of Conformity and USCG approval number if applicable (see first page).