

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED). This Certificate is issued by DNV GL SE based on the notification of the Federal Maritime and Hydrographic Agency of Germany.

This is to certify:

That the Primary deck coverings

with type designation(s)
SCHÖNOX MDE-SF-I + 200 (Gew.-%) Sand (0,1-3 mm)

Issued to

Sika Deutschland GmbH
Rosendahl, Germany

is found to comply with the requirements in the following Regulations/Standards:

Regulation **(EU) 2017/306,**

item No. MED/3.1. SOLAS 74 as amended, Regulation II-2/4, II-2/6 & X/3, 2000 HSC Code 7 and IMO 2010 FTP Code


Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2020-01-28**.

Issued at **Hamburg** on **2017-06-14**

DNV GL local station:
Essen

Approval Engineer:
Sven Jahnke



Notified Body
No.: **0098**

for **DNV GL SE**

Sven Dudzus
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the "Agreement between the European Community and the United States of America on Mutual Recognition of Certificates of Conformity for Marine Equipment", signed February 27th, 2004.

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV GL SE of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.



Product description

"SCHÖNOX MDE-SF-I + 200 (Gew.-%) Sand (0,1-3mm)"
is a cement-bounded primary deck covering, tested on 3mm steel plate.

Mixing ratio:	6l water / 25kg SCHÖNOX MDE-SF-I + 200 % (m/m) sand (grain size 0,1 - 3mm)
Range of application:	5 to 30mm thickness
Approved colour:	grey
Density:	1.8kg/m ³

For further details see test report as referred below.

Application/Limitation

Primary deck covering, not generating excessive quantities of smoke nor toxic products in fire.

Not to be used as an integrated part of horizontal class A division unless tested as such.

The product may be applied over any steel or non-combustible material.

The product may also be used as floor covering.

Each product is to be supplied with its manual for installation and use.

Type Examination documentation

Test Report No. 2014-1569 dated 2014-06-06 issued by Exova Warringtonfire, Frankfurt, Germany.

Tests carried out

Tested according to IMO 2010 FTP Code Annex 1, Part 5 and Annex 2, item 2.2

Marking of product

The product or packing is to be marked with name of manufacturer, type designation, MED Mark of Conformity and USCG approval number if applicable (see first page).