DNV·GL

Certificate No:
MEDB00004HZ

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED). This Certificate is issued by DNV GL SE based on the notification of the Federal Maritime and Hydrographic Agency of Germany.

This is to certify:

That the Fixed fire detection and fire alarm systems components for control stations, service spaces, accommodation spaces, cabin balconies, machinery spaces and unattended machinery spaces: Cables

with type designation(s)
CHJ85/SC, CHJP85/SC, CHJ86/SC, CHJP86/SC

Issued to
Changzhou Marine Cable Co., Ltd. (CMC)
CHANGZHOU, JIANGSU, China

is found to comply with the requirements in the following Regulations/Standards:
Regulation **(EU) 2018/773,**
item No. MED/3.51i. SOLAS 74 as amended, Regulation II-2/7 & X/3, 1994 HSC Code 7, 2000 HSC Code 7, FSS Code 9 and IMO MSC.1/Circ.1242

Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2024-04-01**.

Issued at **Hamburg** on **2019-04-02**

DNV GL local station:
Nanjing

Approval Engineer:
Carsten Hunsalz

Notified Body
No.: **0098**

for **DNV GL SE**

Gerhard Aulbert
Head of Notified Body

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.
This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV GL SE of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.
Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Job Id: **344.1-008610-1**
Certificate No: **MEDB00004HZ**

Product description

XLPE insulated and SHF1 or SHF2 sheathed shipboard control and instrumentation cables.

Type: CHJ85/SC, CHJP85/SC, CHJ86/SC, CHJP86/SC,

Rated voltage: 150/250 V
Maximum operating conductor temperature: 90° C
Conductor: Tinned or plain stranded copper
Insulation: XLPE
Individual screen: Copper wire braid or taped screen (CHJP85/SC, CHJP86/SC only)
Inner covering: Tape
Screen: Copper wire braid
Outer sheath: 5 - SHF2, 6 - SHF1

Number of Pairs	Conductor cross section [mm^2]	
1, 2, 3, 4, 5, 7, 8, 10, 12, 14, 16, 19, 24	0.5, 0.75, 1, 1.5	

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Control and Instrumentation.
Flame retardant Cat. A. Low smoke.

Type Examination documentation

Test report: No. (2017)GJYDX-WT5504 / -WT5505 / -WT5506 / -WT7474
No. CT14-4163-1, CT14-4163-2, (2019)GJYDX-WT0925, (2019)GJYDX-WT0926
Changzhou Marine Cable Co., Ltd. (CMC) dated 2005-05-02

Data sheet: Changzhou Marine Cable Co., Ltd. (CMC) TAC5 & TAC6 (Amend. 2005-4)

Tests carried out

-IEC/EN 60332-1-2:2004+A1:2015
-IEC 60092-376:2017

The following standards are fulfilled in addition:

Standard	Release	General description	Limitation
IEC 60092-350	2014-08	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-376	2017-05	Cables for control and instrumentation circuits 150/250 V (300 V)	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60332-1-2	2015-07	Tests on electric cables under fire conditions. Test for vertical flame propagation for a single insulated wire or cable.	
EC 60332-3-22	2018-07	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Charred portion of sample does not exceed 2,5m above bottom edge of burner.
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 61034-1/2	2013-06	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance >60%

Marking of product

For identification to this type examination certificate the product or packing is to be marked with:

- Manufacturer's name
- Type designation and fire-technical rating

Changzhou Marine Cable Co., Ltd. (CMC) - CHJPJ85/SC - 150/250V - size - IEC 60332-3-22

- Mark of Conformity According to Article 10 of the Council Directive (MED)

END OF CERTIFICATE