DNV·GL

Certificate No:
MEDB00004N2

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED). This Certificate is issued by DNV GL SE based on the notification of the Federal Maritime and Hydrographic Agency of Germany.

This is to certify:

That the Fire dampers

with type designation(s)
CFH, CFHII, CFHIIC

Issued to
Taizhou Hujiang Special Equipment Co., Ltd.
Taizhou, China

is found to comply with the requirements in the following Regulations/Standards:
Regulation **(EU) 2018/773,**
item No. MED/3.22. SOLAS 74 as amended, Regulation II-2/9 and IMO 2010 FTP Code

Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2023-12-11**.

Issued at **Hamburg** on **2018-12-12**

DNV GL local station:
Jiangyin

Approval Engineer:
Marcin Tobiasz

Notified Body
No.: **0098**

for **DNV GL SE**

Sven Dudszus
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the "Agreement between the European Community and the United States of America on Mutual Recognition of Certificates of Conformity for Marine Equipment", signed February 27th, 2004.

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.
This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV GL SE of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.
Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Product description

"CFH, CFHII, CFHIIC"
is a single-bladed rectangular fire damper with manual, electrical or pneumatic driven actuators, all with a fusible link. The following fire dampers construction were tested:

Fire Damper	Coaming thickness [mm]	Coming length on unexposed side [mm]	Damper body wall thickness [mm]	Blade max. size W x H x t [mm]
CFH320×1000-Q	5	500	5	312 x 990 x 4
CFHIIC320×1000-S	5	500	5	312 x 990 x 30
CFHII320×1000-S	5	500	5	312 x 990 x 30

The fire dampers are flanged to the coaming using M14x40 bolting. Casing are insulated for: CFH320×1000-Q, CFHIIC320×1000-S, CFHII320×1000-S. Blades are insulated for: CFHIIC320×1000-S and CFHIIC320×1000-S.

Insulation of casing:
Two layers of LZ-2 type ceramic wool produced by Yixing Kunhao Fireproof Material Co., Ltd with 20 mm nominal thick and density of 170 kg/m^3.

Insulation of blades core:
DJS type superlight polycrystalline filament produced by Zhejiang Pusen New Material Technology Co., Ltd. with density of 116 kg/m^3.

For further details, see Type Examination documentation below.

Application/Limitation

The fire dampers are approved for installation in class A-30 and A-60 steel bulkheads. Other applications are subject to case-by-case approval.

Fire Damper	Max. size	Max. number of blades	Actuator type	Application
CFH320×1000-Q	320 x 1000 mm (W x H)	1	Manual/Electric/Pneumatic	A30
CFHIIC320×1000-S	320 x 1000 mm (W x H)	1	Manual/Electric/Pneumatic	A60
CFHII320×1000-S	320 x 1000 mm (W x H)	1	Manual/Electric/Pneumatic	A60

Actuators to be used (*):
- Manual SKZB,
- Electric BLF230,
- Pneumatic αA-125SR.

(*) Actuators of same brand but with different size as mentioned above may also be used, provided that they have sufficient torque, similar installation arrangement and equivalent fire technical and functional properties.

The fire damper is to be fitted with open/close indication and shall be easily accessible.

The insulation used is to be regarded as minimum insulations for all fire rating and is not to be removed if the fire damper is to be used in division with lower fire ratings.

Each product is to be supplied with its manual for installation, use and maintenance.

Type Examination documentation

Test report no. FT17121 dated 13 June 2017, issued by from Far East Fire Testing Centre, Shanghai, China.

Drawings No.:

- CFHa×b-S(Z)(Q)-00.00 (11 sheets) dated 14 June 2018,
- CFHIICa×b-S(Z)(Q)-00.00 (11 sheets) dated 14 June 2018,
- CFHIIa×b-S(Z)(Q)-00.00 (11 sheets) dated 14 June 2018,

all above from manufacturer.

Tests carried out

Tested according to IMO 2010 FTP Code, Annex 1, part 3.

Marking of product

The product is to be marked with name and address of manufacturer, type designation, fire technical rating, the MED Mark of Conformity and USCG Approval Number if applicable (see first page).