DNV·GL

Certificate No:
**MEDB00004S5**

# EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED). This Certificate is issued by DNV GL SE based on the notification of the Federal Maritime and Hydrographic Agency of Germany.

## This is to certify:

**That the Non-combustible materials**

with type designation(s)
**SprayMix S Type Rock Wool Product**

Issued to
**Hebei NewTime Foundation Fire Insulation materials Manufacturing Co., Ltd.**
**Tangshan, Hebei Province, China**

is found to comply with the requirements in the following Regulations/Standards:
Regulation **(EU) 2018/773,**
**item No. MED/3.13. SOLAS 74 as amended, Regulation II-2/3 II-2/5, II-2/9 & X/3, 2000 HSC Code 7 and IMO 2010 FTP Code**

Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2024-05-22**.

Issued at **Hamburg** on **2019-05-23**

DNV GL local station:
**Tianjin**

Approval Engineer:
**Roland Priebe**

Notified Body
No.: **0098**

for **DNV GL SE**

**Gerhard Aulbert**
**Head of Notified Body**

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the "Agreement between the European Community and the United States of America on Mutual Recognition of Certificates of Conformity for Marine Equipment", signed February 27th, 2004.

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.
This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV GL SE of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.
Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.


© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

## Product description

"SprayMix S Type Rock Wool Product"
is composed of SprayMix S type marine fireproof thermal insulating and noise reducing spraying fibre and the matched GPA/GPB two-component mineral wool adhesive. It is 20 - 60 mm thick and apperes in gray-green colour.

Density (nominal): 140 kg/m3
Organic content: 1.2 %

For further details please see the test report mentioned under "Type Examination documentation" below

## Application/Limitation

Approved for use as non-combustible material.

The product may be used as an integrated part of approved fire resisting divisions only when tested as such.

Each product is to be supplied with its manual for installation and use.

## Type Examination documentation

Test report nos. FT17288 dated 2017-12-25 issued by Far East Testing Centre, Shanghai, China.

## Tests carried out

Tested according to IMO Res. MSC.307(88) - 2010 FTP Code, Annex 1, Part 1.

## Marking of product

The product or packing is to be marked with name and address of manufacturer, type designation, the MED Mark of Conformity and USCG approval number if applicable (see page 1).