

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED). This Certificate is issued by DNV GL SE based on the notification of the Federal Maritime and Hydrographic Agency of Germany.

This is to certify:

That the Fire dampers

with type designation(s)

Rectangular Fire Damper CF-D-J

Issued to

Taizhou Qiankun Shipping Machinery Co., Ltd.
Taixing, China

is found to comply with the requirements in the following Regulations/Standards:

Regulation **(EU) 2018/773**,

item No. MED/3.22. SOLAS 74 as amended, Regulation II-2/9 and IMO 2010 FTP Code

Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2024-09-22**.


Issued at **Hamburg** on **2019-09-23**

DNV GL local station:

Jiangyin

Approval Engineer:

Timo Linn



Notified Body
No.: **0098**

for **DNV GL SE**

Gerhard Aulbert
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the "Agreement between the European Community and the United States of America on Mutual Recognition of Certificates of Conformity for Marine Equipment", signed February 27th, 2004.

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV GL SE of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.



Product description

Rectangular Fire Damper CF-D-J max. clear opening size: 300 x 400mm. The fire damper can be activated automatically by fusible metal rod (70°C +/-3°C), manually, pneumatically or by electrical operated system. The blade consist of 1.2mm steel plate + ceramic wool + 4mm steel plate. Damper body wall thickness: 5mm.

The fire damper is flanged to the coaming using M8 bolting. Coaming /sleeve is made of 5mm thick steel and seal welded to the steel deck. Length between coaming flange and steel bulkhead is min. 450mm on exposed side, and min. 500mm on unexposed side. Casing and blades have been insulated.

Insulation:

Casing: ceramic wool, nominal density 170 kg/m³, manufactured by Yixing Ocean Ship Material Co.,Ltd.

The insulation material of 20mm ceramic wool, density 170 kg/m³ used on coaming and fire damper is to be regarded as minimum insulations for all fire rating and is not to be removed if the fire damper is to be used in division with lower fire ratings.

For further details, see Type Examination documentation below.

Application/Limitation

Approved for use in ducts penetrating class A-60 steel deck.

The damper shall be capable of being closed from both sides of the deck

Type: CF-D-J

Maximum size of damper: 360 x 460mm

Maximum number of blades: 1

Actuator to be used:

- BLF230 type marine electrical actuator manufactured by BELIMO.

Actuation is done manually or automatically by thermal triggering device (bulb) combined with an pneumatic spring return actuator (see below) or electrical actuator.

(*) Actuators of same make but with different size as mentioned above may also be used, provided that they have sufficient torque, similar installation arrangement and equivalent fire technical and functional properties.

Steel thickness of damper casing to be equal to or greater than thickness of duct/sleeve required by the rules, if the damper casing is part of the duct/sleeve.

The fire damper is to be fitted with open/close indication and shall be easily accessible.

Each product is to be supplied with its manual for installation, use and maintenance.

Type Examination documentation

Test Report No. FT18319 dated 2019-02-28 issued by Far East Fire Testing Centre, Shanghai, China.

Tests carried out

Tested according to IMO 2010 FTP Code Annex1, Part 3.

Marking of product

The product is to be marked with name and address of manufacturer, type designation, fire-technical rating, MED Mark of Conformity and USCG approval if applicable.