

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED). This Certificate is issued by DNV GL SE based on the notification of the Federal Maritime and Hydrographic Agency of Germany.

This is to certify:

That the "A" Class divisions, fire integrity

with type designation(s)
HLBA60(100Y)

Issued to

Tianjin Huali Thermal Insulation Building Material Co., Ltd.
TIANJIN, China

is found to comply with the requirements in the following Regulations/Standards:

Regulation **(EU) 2018/773**,

item No. MED/3.11a. SOLAS 74 as amended, Regulation II-2/3.2 & II-2/9, IMO 2010 FTP Code, IMO MSC/Circ.1120 and IMO MSC.1/Circ.1434


Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2024-08-06**.

Issued at **Hamburg** on **2019-08-07**

DNV GL local station:
Tianjin

Approval Engineer:
Roland Priebe



Notified Body
No.: **0098**

for **DNV GL SE**

Gerhard Aulbert
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the "Agreement between the European Community and the United States of America on Mutual Recognition of Certificates of Conformity for Marine Equipment", signed February 27th, 2004.

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV GL SE of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.



Job Id: **344.1-009524-1**
Certificate No: **MEDB00005KY**

Product description

The Class A-60 bulkhead **HLBA60(100Y)** consists of a core steel plate with stiffeners. The bulkhead is insulated on the stiffeners side.

Construction:

The core steel plate is 4.5 mm thick and stiffened at interval of 600 mm. The stiffeners are of L63 x 63 x 6 mm angle steel.

Insulation:

The insulation material is THY-100 type rock wool from the applicant himself. It is nominal 50 mm and 30 mm thick, has a nominal density of 100 kg/m³ and 1.9 % organic content.

The insulation material is applied on the surface of the stiffened side with one layer of 50 mm and on the stiffeners with one layers of 30 mm thick insulation. It is fixed with pins with a max. distance between the pins of 300 mm on the core steel plate and of max. 200 mm on stiffeners and rock wool seams. The pins are 3 mm in diameter and the securing washers are 30 mm in diameter, both made of steel.

For further details refer to the documentation listed below under "Type Examination documentation".

Application/Limitation

Approved for use as a vertical fire retarding division of class A-60.

The insulation materials and adhesives used have to be approved according to the Marine Equipment Directive and bear the Mark of Conformity. This requirement may also be applicable for surface materials used, if required by relevant rules and regulations.

Each product is to be supplied with its manual for installation, use and maintenance.

Type Examination documentation

Test report no. FT18029 dated 2018-02-26 issued by Far East Fire Testing Centre, Shanghai, China.

Tests carried out

Tested according to IMO Resolution MSC.307(88) – 2010 FTP Code Annex 1, Part 3.

Marking of product

The product or packing is to be marked with name and address of manufacturer, type designation, fire technical rating, the MED Mark of Conformity and USCG approval number (see page 1).