DNV·GL

Certificate No:
MEDB00006DA

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV GL AS under the authority of the Government of Norway.

This is to certify:

That the Fire Doors

with type designation(s)
XFD - H - A60, Type 03

Issued to
METALLTEKNIKK AS
BRYNE, Norway

is found to comply with the requirements in the following Regulations/Standards:
Regulation **(EU) 2019/1397,**
item No. MED/3.16. SOLAS 74 as amended, Regulation II-2/9, IMO 2010 FTP Code and IMO MSC.1/Circ.1511, IMO MSC.1/Circ.1319

Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2025-01-23**.
Issued at **Høvik** on **2020-01-24**

DNV GL local station:
Norway CMC, West

Approval Engineer:
Synnøve Bolstad Eri

Notified Body
No.: **0575**

for **DNV GL AS**

Roald Vårheim
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the "Agreement between the United States of America and the EEA EFTA states on the mutual recognition of Certificates of Conformity for Marine Equipment" signed 17 October 2005, and amended by Decision No 1/2019 dated February 22nd, 2019.

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.
This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV GL AS of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.
Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

NORWEGIAN ACCREDITATION PROD 019

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Product description

"XFD - H - A60, Type 03"
is a single leaf door with doorblades composed of 2.0 mm stainless steel plates on each side of an insulation core of 63 mm, composed of two layers (1x38 mm and 1x25 mm) of Superwool 607 Plus Blanket, manufactured by Morgan Thermal Ceramics, UK, with a nominal density of 128 kg/m³.

Total thickness of door leaf: 67 mm.

The door blade is to be fitted with three hinges.

The door may be fitted with:
- Window: Pilkington Pyrostop 60-201, 27 x 540 x 240 mm (T x H x W)
- Hose port: 190 mm x 190 mm (Wx H)

The door frame is made of 3 mm tick steelplate, bolted to the bulkhead c/c 210 mm on vertical edges and c/c 220 in the top. The door frame may also be welded to the bulkhead.

For further details, please see drawing listed under type examination documentation below.

Application/Limitation

The door is approved for installation in steel bulkheads of class A-60. Installation of the door in bulkheads made of other materials (aluminium, FRP, etc.) are subject to case-by-case approval.

Maximum size of door leaf:	1050 x 2222 mm (W x H)
Maximum clear opening, door:	950 x 2110 mm (W x H)
Maximum clear opening, window:	510 x 211 mm (H x W)

The insulation materials and adhesives used have to be approved according to the Marine Equipment Directive and bear the Mark of Conformity. This requirement may also be applicable for surface materials used, if required by relevant rules and regulations.

The product is to be supplied with its manual for installation, maintenance and use.

Type Examination documentation

Test report no. PGA10634, Serial no.14928 dated 6 February 2015 from DBI, Hvidovre, Denmark.

Drawing no. 200009 (7 sheets) dated 4 November 2014 from Xnor, Sandnes Norway.

Tests carried out

Tested according to IMO 2010 FTP Code part 3.

Marking of product

The product is to be marked with name and address of manufacturer, type designation, fire-technical rating, MED Mark of Conformity and USCG approval number if applicable (see page 1).

USCG approval limitation

The approval is limited to fire doors without windows and doors with total window area of 645 cm², or less, in each door leaf. Doors with a window area exceeding 645 cm² are not part of this certificate and need direct USCG approval.