DNV·GL

Certificate No:
MEDB00006DJ

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV GL AS under the authority of the Government of Norway.

This is to certify:

That the Fixed fire detection and fire alarm systems components for control stations, service & accom. spaces, cabin balconies, machinery spaces & unattended machinery spaces: Smoke detectors – Point detectors using scattered or transmitted light or ionization

with type designation(s)
Interactive fire detectors

Issued to
Autronica Fire and Security AS
Trondheim, Norway

is found to comply with the requirements in the following Regulations/Standards:
Regulation **(EU) 2019/1397,**
item No. MED/3.51d. SOLAS 74 as amended, Regulation II-2/7 & X/3, 1994 HSC Code 7, 2000 HSC Code 7, FSS Code 9, IGF Code 11 and IMO MSC.1/Circ.1242
item No. MED/3.51c. SOLAS 74 as amended, Regulation II-2/7 & X/3, 1994 HSC Code 7, 2000 HSC Code 7, FSS Code 9 and IMO MSC.1/Circ.1242

Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2025-02-13**.

Issued at **Høvik** on **2020-02-14**

DNV GL local station:
Trondheim

Approval Engineer:
Ståle Sneen

Notified Body
No.: **0575**

for **DNV GL AS**

Roald Vårheim
Head of Notified Body

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.
This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV GL AS of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.
Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

NORWEGIAN ACCREDITATION PROD 019

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Job Id: **344.1-001925-14**
Certificate No: **MEDB00006DJ**

Product description

Interactive fire detectors designed according to EN54 for use with Autronica's interactive fire detection systems:

BH-200 (Note 1)	Smoke detector without SelfVerify
BH-300 (Note 1)	Smoke detector with SelfVerify
BH-500 (Note 1)	Smoke detector with SelfVerify, environmentally protected
BH-500/N (Note 1)	Smoke detector with SelfVerify, Exic-version for use in zone 2 only
BH-500/EX (Note 1)	Smoke detector with SelfVerify, Exia-version for use in all zones
BH-220 (Note 1)	Multisensor detector without SelfVerify
BH-320 (Note 1)	Multisensor detector with SelfVerify
BH-520 (Note 1)	Multisensor detector with SelfVerify, environmentally protected
BH-520/N (Note 1)	Multisensor detector with SelfVerify, Exic-version for use in zone 2 only
BH-520/EX (Note 1)	Multisensor detector with SelfVerify, Exia-version for use in all zones

Note 1: The detector head carries an additional H in the name. The listed products includes the mandatory socket BWA-100.

Application/Limitation

The equipment are found to comply with following location/application dependent requirements (for definition of each of the location classes, see below the table):

MODEL	TEMPERATURE	VIBRATION	EMC	ENCLOSURE
BH-200	TEM-D	VIB-B	EMC-B	ENC-B
BH-300	TEM-D	VIB-B	EMC-B	ENC-B
BH-500	TEM-D	VIB-B	EMC-B	ENC-B
BH-500/N	TEM-D	VIB-B	EMC-B	ENC-B
BH-500/EX	TEM-D	VIB-B	EMC-B	ENC-B
BH-220	TEM-D	VIB-B	EMC-B	ENC-B
BH-320	TEM-D	VIB-B	EMC-B	ENC-B
BH-520	TEM-D	VIB-B	EMC-B	ENC-B
BH-520/N	TEM-D	VIB-B	EMC-B	ENC-B
BH-520/EX	TEM-D	VIB-B	EMC-B	ENC-B

Definition of the location classes with reference to relevant standards:
- Temperature: TEM-D – Location (-25°C-70°C) (ref. IEC 60092-504:2016 table 1 item 6-7)
- Vibration: VIB-B – On reciprocating machines etc. (ref. IEC 60092-504:2016 table 1 item 10)
- EMC: EMC-B – Bridge and open deck zone (ref. IEC 60092-504:2016 table 1 item 13-20)
- Enclosure: ENC-B – Engine room (IP44) (ref. IEC 60092-201:1994 table 5)

Ex installations to be approved in each case according to the Rules and Ex-Certification/ Special Condition for Safe Use listed in valid Ex-certificate issued by a notified/recognized Certification Body.

Ex-certification is not covered by this certificate and the following paragraph, which is for information only, is based on information received from the manufacturer, but not verified by DNV GL.

Information on Ex-Certification received from manufacturer – Not verified by DNV GL				
Equipment	Certified			Certificate No.
BHH-500/EX BHH-520/EX	Ⓔx II 1G	Ex ia IIC T5	Ta: -20°C to +70°C	Nemko 03ATEX218X
BHH-500/N BHH-520/N	Ⓔx II (3)G Ⓔx II 3G	[Ex ic Gc] IIB Ex ic IIB T4 Gc	Ta: -20°C to +70°C Ta: -20°C to +70°C	Nemko 03ATEX217X

Type Examination documentation

Equipment	Scope	Document	No.
BH-200	EN 54-7	ANPI, Test Report, BFS/REDI/154-2005.06.03 ANPI, Test Report, BFS/DE/1057-1999.12.09 incl. ANPI, Addendum, Nr.1 2000-02-25	1 2
	IEC60092-504, IEC60533	DNV, Test Report, 99-1491, rev.2 DNV, Test Report, 2000-1178, rev.2 Nemko, Test report (supplemental), E18217.00	4 5 152
	Product data	Autronica, Data Sheet, 116-P-BH200, rev.C	14
BH-300	EN 54-7	ANPI, Test Report, BFS/REDI/154-2005.06.03 ANPI, Test Report, BFS/DE/1057-1999.12.09 incl. ANPI, Addendum, Nr.1 2000-02-25	1 2
	IEC60092-504, IEC60533	DNV, Test Report, 99-1491, rev.2 DNV, Test Report, 2000-1178, rev.2 Nemko, Test report (supplemental), E18217.00	4 5 152
	Product data	Autronica, Data Sheet, 116-P-BH300, rev.C	15
BH-500	EN 54-7	ANPI, Test Report, BFS/REDI/154-2005.06.03 ANPI, Test Report, BFS/DE/1057-1999.12.09 incl. ANPI, Addendum, Nr.1 2000-02-25	1 2
	IEC60092-504, IEC60533	DNV, Test Report, 99-1491, rev.2 DNV, Test Report, 2000-1178, rev.2 Nemko, Test report (supplemental), E18217.00	4 5 152
	Product data	Autronica, Data Sheet, 116-P-BH500, rev.G	16
BH-500/N	EN 54-7	ANPI, Test Report, BFS/REDI/154-2005.06.03 ANPI, Test Report, BFS/DE/1057-1999.12.09 incl. ANPI, Addendum, Nr.1 2000-02-25	1 2
	IEC60092-504, IEC60533	DNV, Test Report, 99-1491, rev.2 DNV, Test Report, 2000-1178, rev.2 Nemko, Test report (supplemental), E18217.00	4 5 152
	Product data	Autronica, Data Sheet, 116-P-BH500N/CGB, rev.A	125
BH-500/EX	EN 54-7	ANPI, Test Report, BFS/REDI/154-2005.06.03 ANPI, Test Report, BFS/DE/1057-1999.12.09 incl. ANPI, Addendum, Nr.1 2000-02-25	1 2
	IEC60092-504, IEC60533	DNV, Test Report, 2000-1178, rev.2 Nemko, Test report (supplemental), E18217.00	5 152
	Product data	Autronica, Data Sheet, 116-P-BH500EX/CGB, rev.H	124
BH-220	EN 54-5/7	ANPI, Test Report, BFS/REDI/154-2005.06.03 ANPI, Test Report, BFS/DE/1057-1999.12.09 ANPI, Addendum, Nr.1 2000-02-25	1 2 3
	IEC60092-504, IEC60533	DNV, Test Report, 99-1491, rev.2 DNV, Test Report, 2000-1178, rev.2 Nemko, Test report (supplemental), E18217.00	4 5 152
	Product data	Autronica, Data Sheet, 116-P-BH220, rev.D	21
BH-320	EN 54-5/7	ANPI, Test Report, BFS/REDI/154-2005.06.03 ANPI, Test Report, BFS/DE/1057-1999.12.09 ANPI, Addendum, Nr.1 2000-02-25	1 2 3
	IEC60092-504, IEC60533	DNV, Test Report, 99-1491, rev.2 DNV, Test Report, 2000-1178, rev.2 Nemko, Test report (supplemental), E18217.00	4 5 152
	Product data	Autronica, Data Sheet, 116-P-BH320, rev.D	22
BH-520	EN 54-5/7	ANPI, Test Report, BFS/REDI/154-2005.06.03 ANPI, Test Report, BFS/DE/1057-1999.12.09 ANPI, Addendum, Nr.1 2000-02-25	1 2
	IEC60092-504, IEC60533	DNV, Test Report, 99-1491, rev.2 DNV, Test Report, 2000-1178, rev.2 Nemko, Test report (supplemental), E18217.00	4 5 152

Equipment	Scope	Document	No.
	Product data	Autronica, Data Sheet, 116-P-BH520, rev.F	23
BH-520/N	EN 54-5/7	ANPI, Test Report, BFS/REDI/154-2005.06.03 ANPI, Test Report, BFS/DE/1057-1999.12.09 ANPI, Addendum, Nr.1 2000-02-25	1 2
	IEC60092-504, IEC60533	DNV, Test Report, 99-1491, rev.2 DNV, Test Report, 2000-1178, rev.2 Nemko, Test report (supplemental), E18217.00	4 5 152
	Product data	Autronica, Data Sheet, 116-P-BH520N/CGB, rev.A	127
BH-520/EX	EN 54-5/7	ANPI, Test Report, BFS/REDI/154-2005.06.03 ANPI, Test Report, BFS/DE/1057-1999.12.09 ANPI, Addendum, Nr.1 2000-02-25	1 2
	IEC60092-504, IEC60533	DNV, Test Report, 2000-1178, rev.2 Nemko, Test report (supplemental), E18217.00	5 152
	Product data	Autronica, Data Sheet, 116-P-BH520EX/CGB, rev.H	126

Tests carried out

Applicable tests according to:
- EN 54-5:2000 incl. A1:2002 (for multisensor)
- EN 54-5:2017 incl. A1:2018 (for multisensor)
- EN 54-7:2018
- IEC 60092-504:2016
- IEC 60533:2015

Marking of product

For identification to this type examination certificate the products shall be marked with:
- Manufacturer's name or trade mark
- Type designation
- Mark of Conformity (wheel mark), followed by
    - identification number of the NoBo involved in production control (MED D)
    - the year the mark is affixed
    - Example: 0575/2020