



EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate No:
MEDB00008HV

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED). This Certificate is issued by DNV GL SE based on the notification of the Federal Maritime and Hydrographic Agency of Germany.

This is to certify:

That the Expansion foam for fixed fire extinguishing systems for chemical tankers

with type designation(s)
SOLBERG VERSAGARD AS-100 FP

Issued to

AUXQUIMIA S.A.U. (Perimeter Solutions)
Mieres, Asturias, Spain

is found to comply with the requirements in the following Regulations/Standards:

Regulation (EU) 2023/1667,
item No. MED/3.59. SOLAS 74 as amended IMO Res. MSC.4(48)-(IBC Code) 11, Reg. II-2/1, IMO MSC/Circ.553
and IMO MSC.1/Circ.1312 incl. Corr.1


Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2028-10-30**.

Issued at **Hamburg** on **2023-10-31**

DNV local unit:
Area NB/CMC Iberia

Approval Engineer:
Helge Bjørnara



Notified Body
No.: **0098**

for **DNV GL SE**

Christine Mydlak-Roeder
Head of Notified Body

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.
This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV GL SE of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.
Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

"SOLBERG VERSAGARD AS-100 FP"

is a synthetic, not fluorinated, alcohol resistant foam concentrate (S-AR).

Application/Limitation

Approved for use as a low expansion, multi-purpose foam forming liquid (Type A) for fixed and mobile fire-fighting systems.

Description	SOLBERG VERSAGARD AS-100 FP
Nominal mixing ratio with seawater:	3 %
Kinematic viscosity (20 °C):	N/A, it is a non-Newtonian liquid
pH value (20 °C):	7
Expansion ratio:	8.1
Drainage time (25%):	23:06 (min:s)
Volumetric mass/density (20 °C):	1.04 g/ml
Temperature, storage and usage:	0 °C to 50 °C (32 °F to 122 °F)
Onboard tank/ storage material:	To be stored in the original supplied package (HDPE totes, drums, or pails) or according to technical bulletin no. PSS-2022091.
Foam use, filling, maintenance, storage, transport, etc. are to be in accordance with the manufacturer's instructions	

The validity of the certificate is dependent on the compliance of each manufactured product with the prototype which underwent the type approval tests and such compliance shall be stated by the manufacturer.

The storage facilities and piping arrangement onboard the vessels are to be designed and constructed with regard to seawater exposure (where applicable), and the minimum allowed temperature for the foam liquid.

Non-Newtonian, pseudo plastic foam concentrate. This concentrate can require special proportioning equipment.

This approval does not address the foam generating equipment, only the foam concentrate.

The foam concentrate does not contain PFOS.

Each product is to be supplied with its manual for application, use, storage, transport and maintenance.

Periodical controls of foam concentrates stored on board (to be done in accordance with IMO MSC.1/Circ.1312):

- The foam liquid is to be delivered with a declaration of conformity and a declaration of the main characteristics (sedimentation, pH-value, expansion ratio, drainage time and volumetric mass). The declaration will be the basis for the annual condition test (each year after 3 years).

Type Examination documentation

Declaration of conformity no. KB 38/23 dated 31 May 2023 from MPA Dresden GmbH, Freiberg, Germany.

Test Report No. 20230210/Aux 09 dated 31 May 2023 from MPA Dresden, Freiberg, Germany.

Tests carried out

Tested according to IMO MSC.1/Circ.1312 and IMO MSC.1/Circ.1312/Corr.1

Marking of product

The packing is to be marked with MED Mark of Conformity and according to IMO MSC.1/Circ.1312, 3.13, including among other things name and address of manufacturer, type designation, storage/use temperature, production date, expiry date and SHE information.