

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate No:
MEDB00008RS

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED). This Certificate is issued by DNV GL SE based on the notification of the Federal Maritime and Hydrographic Agency of Germany.

This is to certify:

That the A & B Class divisions fire integrity: B class divisions.

with type designation(s)

CFM-AD3 Type B-15 Class Ceiling Access Door

Issued to

Jiangyin Dongrui Decoration Materials Co., Ltd
Jiangyin, JIANGSU, China

is found to comply with the requirements in the following Regulations/Standards:

Regulation (EU) 2023/1667,

item No. MED/3.11b. SOLAS 74 as amended, Regulation II-2/3.4 & II-2/9, IMO 2010 FTP Code, IMO MSC/Circ.1120 and IMO MSC.1/Circ.1581


Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2029-01-17**.

Issued at **Hamburg** on **2024-01-18**

DNV local unit:
Jiangyin NB & CMC

Approval Engineer:
Karolina Kusmider



Notified Body
No.: **0098**

for **DNV GL SE**

Mydlak-Röder, Christine
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV GL SE of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

"CFM-AD3 Type B-15 Class Ceiling Access Door"

is a hatch composed of 24.8mm thick of KMD-Y type marine rock wool (density 120 kg/m³, produced by Tianchang KMD New Insulation Materials) faced from both sides with 0.6 mm thick steel plates.

The steel plate and the insulation is glued to each other with adhesive. Fireproof sealing strips (12 mm x 4 mm) are filled around hatch leaf and frame.

The hatch is connected to the 1.5 mm thick frame by a pair of rectangular stainless steel hinges at one side of leaf.

The hatch leaf is equipment with a C-J type lock produced by Nantong Hujiang Marine Technology.

Total thickness of hatch leaf: 25 mm

For further details see drawing(s) listed under Type Examination documentation.

Application/Limitation

Approved for use as an integrated part of a horizontal fire retarding division of class B-15.

Approved for installation in the tested ceiling CLP-C2 type produced by Jiangyin Dongrui Decoration Materials. Installation in other ceilings may be approved case-by-case. Ceiling has to be approved according to the Marine Equipment Directive and bear the Mark of Conformity.

Max. clear opening of the hatch:	400 mm x 600 mm	(W x L)
Max. size of hatch leaf:	424 mm x 623 mm	(W x L)
Max. cut out in ceiling:	430 mm x 630 mm	(W x L)

The insulation materials and adhesives used have to be approved according to the Marine Equipment Directive and bear the Mark of Conformity. This requirement may also be applicable for surface materials used, if required by relevant rules and regulations.

Each product is to be supplied with its manual for installation and maintenance.

Type Examination documentation

Test report No. FT23242 dated 18 July 2023 from FEFTC, Shanghai, China.

Drawing No. 23DR-AD3-T0 dated 14 April 2023 from Manufacturer.
Drawing No. 23DR-AD3-T1 dated 14 April 2023 from Manufacturer.
Drawing No. 23DR-AD3-T2 dated 14 April 2023 from Manufacturer.
Drawing No. 23DR-AD3-T3 dated 14 April 2023 from Manufacturer.
Drawing No. 23DR-AD3-T4 dated 14 April 2023 from Manufacturer.
Drawing No. 23DR-AD3-T5 dated 14 April 2023 from Manufacturer.
Drawing No. 23DR-AD3-T6 dated 14 April 2023 from Manufacturer.
Drawing No. 23DR-AD3-T7 dated 14 April 2023 from Manufacturer.

Tests carried out

Tested according to IMO 2010 FTP Code Part 3.

Marking of product

The product is to be marked with name and address of manufacturer, type designation, fire technical rating, the MED Mark of Conformity and USCG Approval Number if applicable (see first page).