

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate No:
MEDB00008S8

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED). This Certificate is issued by DNV GL SE based on the notification of the Federal Maritime and Hydrographic Agency of Germany.

This is to certify:

That the A & B Class divisions fire integrity: B class divisions.

with type designation(s)

JCP-C7 Type B-15 Class Ceiling/A-15 Class Compound Deck

Issued to

Jiangsu Hailu Technology Incorporated Corporation
JIANGYIN, JIANGSU, China

is found to comply with the requirements in the following Regulations/Standards:

Regulation (EU) 2023/1667,

item No. MED/3.11b. SOLAS 74 as amended, Regulation II-2/3.4 & II-2/9, IMO 2010 FTP Code, IMO MSC/Circ.1120 and IMO MSC.1/Circ.1581


Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2029-03-21**.

Issued at **Hamburg** on **2024-03-22**

DNV local unit:
Jiangyin NB & CMC

Approval Engineer:
Karolina Kusmider



Notified Body
No.: **0098**

for **DNV GL SE**

Mydlak-Röder, Christine
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV GL SE of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

“JCP-C7 Type B-15 Class Ceiling/A-15 Class Compound Deck”

Is the ceiling composed of panels suspended below the structural deck, constructed of two 25 mm thick layer of KMD-Y type rock wool (density of 80 kg/m³, produced by Tianchang KMD New Insulation Materials) and faced with 0.5 mm thick steel plate.

The panels are connected with each other through snaps on the three main suspension beams, which were formed by bending of 0.8 mm galvanized steel plate.

The ceiling is hanging under the A class deck construction with L30 mm x 30 mm x 4 mm angle bars and hangers using M8 screws and screw sleeves. The hangers are made of galvanized plates of 0.8 mm thick and M6 screws.

For further details see documentation listed under Type Examination documentation.

Application/Limitation

Approved for use as a horizontal fire retarding division of class B-15.

When the ceiling panels are suspended minimum 300 mm below a structural steel deck, the whole construction is to be regarded as a fire resisting division of class A-30.

Maximum panel size:	600 mm x 600 mm (W x H/L)
Maximum distance between hangers:	600 mm

The insulation materials and adhesives used have to be approved according to the Marine Equipment Directive and bear the Mark of Conformity. This requirement may also be applicable for surface materials used, if required by relevant rules and regulations.

Each product is to be supplied with its manual for installation and maintenance.

Type Examination documentation

Test report No. FT23385 dated 18 October 2023 from FEFTC, Shanghai, China.

Tests carried out

Tested according to IMO 2010 FTP Code Part 3.

Marking of product

The product is to be marked with name and address of manufacturer, type designation, fire technical rating, the MED Mark of Conformity and USCG Approval Number if applicable (see first page).