

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate no.:
MEDB000095X

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED). This Certificate is issued by DNV SE based on the notification of the Federal Maritime and Hydrographic Agency of Germany.

This is to certify:

that the Surface materials and floor coverings with low flame-spread characteristics: paint systems

with type designation(s)
SikaSeal-641 Fire Coating

issued to

Wolman Wood and Fire Protection GmbH
Illertissen, Germany

is found to comply with the requirements in the following Regulations/Standards:

Regulation (EU) 2024/1975,

item No. MED/3.18b. SOLAS 74, Reg. II-2/3, II-2/5, II-2/6 & X/3, IMO MSC/Circ. 1120, 2000 HSC Code 7 and IMO 2010 FTP Code


Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2029-10-13**.

Issued at **Hamburg** on **2024-10-14**

DNV local unit:
Augsburg

Approval Engineer:
Izabela Misztal



Notified Body
No.: **0098**

for **DNV SE**

Mydlak-Röder, Christine
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the "Agreement between the European Community and the United States of America on Mutual Recognition of Certificates of Conformity for Marine Equipment", signed February 27th, 2004, and amended by Decision No 1/2023 dated May 26th, 2023.

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV SE of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled. Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

"SikaSeal-641 Fire Coating"
is a fire protection coating.

Maximum applied amount of product: 3.661 kg/m²

Maximum thickness: 1.8 mm

Density: 1.44 g/cm³

For further details see Type Examination documentation below.

Application/Limitation

Approved for use as low flame spread surface material, not generating excessive quantities of smoke nor toxic products in fire.

Approved for use as paint systems on any non-combustible substrate.

Approved paint colour: white

Maximum organic content: 47%

The product satisfies the requirement for maximum calorific value (ref. SOLAS Chapter II-2, Reg. 5.3.2.2) without further testing.

Each product is to be supplied with its manual for application and maintenance.

Type Examination documentation

Test report no. 18/0847 dated 11 June 2018 from Currenta GmbH & Co. OHG, Leverkusen, Germany.

Tests carried out

Tested according to IMO 2010 FTP Code Part 5 and Annex 2 item 2.2 and item 2.3.

Marking of product

The product or packing is to be marked with name and address of manufacturer, type designation, the MED Mark of Conformity and USCG approval number if applicable (see first page).