

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate no.:
MEDB000099K

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED). This Certificate is issued by DNV SE based on the notification of the Federal Maritime and Hydrographic Agency of Germany.

This is to certify:

that the **Non-combustible materials**

with type designation(s)
LZ-3 Type Glass Wool

issued to

Yixing Kunhao Fireproof Material Co., Ltd
Yixing, China

is found to comply with the requirements in the following Regulations/Standards:

Regulation (EU) 2024/1975,

item No. MED/3.13. SOLAS 74 as amended, Regulation II-2/3 II-2/5, II-2/9 & X/3, 2000 HSC Code 7 and IMO 2010 FTP Code


Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2029-11-06**.

Issued at **Hamburg** on **2024-11-07**

DNV local unit:
Jiangyin NB & CMC

Approval Engineer:
Marcin Tobiasz



Notified Body
No.: **0098**

for **DNV SE**

Mydlak-Röder, Christine
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV SE of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

"LZ-3 Type Glass Wool"

is glass wool product with nominal density 64 kg/m³ and nominal thickness 20 mm.

For further details Type Examination documentation below.

Application/Limitation

Approved for use as non-combustible material.

Colour: light yellow

Nominal organic content: 6%

The product may be used as an integrated part of approved fire resisting divisions only when tested as such.

The material shrank/collapsed during the non-combustibility test

Each product is to be supplied with its manual for installation and use.

Type Examination documentation

Test report no. FT24315 dated 31 July 2024 from Far East Fire Testing Centre (FEFTC), Shanghai, China.

Tests carried out

Tested according to IMO 2010 FTP code part 1.

Marking of product

The product or packing is to be marked with name and address of manufacturer, type designation, fire-technical rating, the MED Mark of Conformity and USCG approval number if applicable (see first page).