

# TYPE EXAMINATION CERTIFICATE – EC MODULE B

Certificate no.:  
**MEDB00009CX**

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV AS under the authority of the Government of Norway.

## This is to certify:

**that the Fixed fire detection and fire alarm systems components for control stations, service spaces, accommodation spaces, cabin balconies, machinery spaces and unattended machinery spaces: Input/output devices**

with type designation(s)  
**IMC-501,IMC-502,IMC-503,RMC-501,DIC-501**

issued to  
**WUXI BRIGHTSKY ELECTRONIC CO.,LTD**  
**Wuxi City, China**

is found to comply with the requirements in the following Regulations/Standards:

Regulation (EU) 2025/1533,  
item No. MED/3.51h. SOLAS 74 as amended, Regulation II-2/7 & X/3, 1994 HSC Code 7, 2000 HSC Code 7, FSS Code 9, IGF Code 11 and IMO MSC.1/Circ.1242


Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2031-02-04**.

Issued at **Høvik** on **2026-02-05**

DNV local unit:  
**Jiangyin NB & CMC**

Approval Engineer:  
**Heinz Scheffler**



for **DNV AS**

Notified Body  
No.: **0575**

**Mydlak-Röder, Christine**  
**Head of Notified Body**



The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.  
This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV AS of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.  
Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

## Product description

Input/Output modules designed for use with Brightsky's interactive fire alarm system JB-QBC-501.

| Type    | Description                      | Degree of protection |
|---------|----------------------------------|----------------------|
| IMC-501 | Addressable Input module         | IP20                 |
| IMC-502 | Addressable Input module         | IP44                 |
| IMC-503 | Addressable Input module         | IP44                 |
| RMC-501 | Addressable Input/output module  | IP20                 |
| DIC-501 | Addressable Disable input device | IP44                 |

### Technical data:

#### IMC-501:

- Max. 10s response time
- Monitor the input wire broken
- Electrical isolation between input and output wires
- built-in indicator for alarm

#### IMC-502:

- Max. 10s response time
- 2 input mode can be selected: input from open dry contact, conventional detector
- Monitor the wire broken
- Electronic isolation between input and output
- Max. current connected to conventional detector is 25mA

#### IMC-503

- Max. 10s response time
- 2 input mode can be selected: input from open dry contact, conventional detector
- Monitor the wire broken
- Max. current connected to conventional detector is 100mA

#### RMC-501

- Max. 10s response time
- Monitor the input and output device's wire broken
- Electronic isolation between input and output
- built-in indicator for alarm.

#### DIC-501

- Auto-recovery from disables status
- Trigger by mechanical timer, stable and reliable
- built-in indicator for disabled.
- Maximum disabled time is 15 minutes

#### Software-Version:

- IMC-501\_V1.0.AOP2
- IMC502-3\_V1.0.AOP2
- RMC501\_V1.0.AOP2

## Application/Limitation

The equipment is found to comply with following location/application dependent requirements (for definition of each of the location classes, see below the table):

| MODEL                                               | TEMPERATURE | VIBRATION | EMC   |
|-----------------------------------------------------|-------------|-----------|-------|
| IMC-501<br>IMC-502<br>IMC-503<br>RMC-501<br>DIC-501 | TEM-D       | VIB-A     | EMC-B |

Definition of the location classes with reference to relevant standards:

- **Temperature:** TEM-D: Protected (-25°C to +70°C) (ref. IEC 60092-504:2016 table 1 item 6-7)
- **Vibration:** VIB-A: For general applications etc.(±1.0mm/0.7g) (ref. IEC 60092-504:2016 table 1 item 10)
- **EMC:** EMC-B: All locations incl. bridge and open deck (ref. IEC 60092-504:2016 table 1 item 13-20)

## Type Examination documentation

hidden

### Tests carried out

- Applicable tests according to:
- EN 54-18:2005 incl. AC:2007
- IEC 60092-504:2016
- IEC 60533:2015

### Marking of product

For identification to this type examination certificate the products shall be marked with:

- Manufacturer's name or trademark
- Type designation
- Mark of Conformity (wheel mark), followed by:
  - identification number of the NoBo involved in production control (MED D)
  - the year the mark is affixed
  - Example: 0575/2025

END OF CERTIFICATE