

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate no.:
MEDB0000B0Y
Revision no.:
0

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV AS under the authority of the Government of Norway.

This is to certify:

that the **Fixed fire detection and fire alarm systems components for control stations, service spaces, accommodation spaces, cabin balconies, machinery spaces and unattended machinery spaces: - smoke detectors: point detectors using scattered light, transmitted light or ionization**

with type designation(s)
LYNX & ORION smoke detectors

issued to

**FABRICATION d' APPLICATIONS et de REALISATIONS
ELECTRONIQUES FARE**
rue Duhamel du Monceau ZA de la Guinette 45300 DADONVILLE France,

is found to comply with the Implementing Regulation (EU) 2025/1533 for
Item no. **MED/3.51d (Row 1 of 1)**

according to the following requirements:

SOLAS 74 Reg. II-2/7, IMO Res. MSC.36(63)-(1994 HSC Code) 7, IMO Res. MSC.97(73)-(2000 HSC Code) 7, IMO Res. MSC.391(95)-(IGF Code) 11, IMO MSC.1/Circ.1242, SOLAS 74 Reg. X/3, IMO Res.MSC.98(73)-(FSS Code) 9


Further details of the equipment and conditions for certification are given overleaf.

Date of issue: **2026-04-16**

Expiry date: **2031-04-15**

DNV local unit:
France CMC

Approval Engineer:
Frode Nygård



Notified Body
no.: **0575**

for **DNV AS**

Christine Mydlak-Röder
Head of Notified Body



The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV AS of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

Interactive addressable fire detectors according to EN 54.

LYNX-Range:

- LOA Smoke detector
- LOTA Smoke detector equipped with a thermistor (Multisensor).
- LOTAI Smoke detector equipped with a thermistor (Multisensor).
- LOTCA Smoke detector equipped with a thermistor and a CO gas sensor (Multisensor).

ORION ATEX range:

- OC-OIEx Smoke detector Ex-version.

Application/Limitation

The products covered by this certificate have been assessed according to the requirements of item MED/3.51d row 1 of 1, MED/3.51c row 1 of 1 (Multisensor) and item MED/3.51g row 1 of 1 in Regulation (EU) 2025/1533, as found relevant.

Please see further details under Tests carried out.

Please see Appendix: Application/Limitation

Type Examination documentation

Tests carried out

Applicable tests according to:

- EN 54-7:2018,
- IEC 60092-504:2016,
- IEC 60533:2015.

Optional Performance tests for short-circuit isolator,

- EN 54-17:2005 incl. AC:2007 (for LOA, LOTA, LOTAI, LOTCA).

Optional Performance tests for multisensor/multicriteria according to:

- EN 54-5:2017 incl. A1:2018 (for LOTA, LOTAI, LOTCA).

Marking of product

For identification to this type examination certificate the products shall be marked with:

- Manufacturer's name or trade mark
- Type designation
- Mark of Conformity (wheel mark), followed by
 - identification number of the NoBo involved in production control (MED D)
 - the year the mark is affixed
 - Example: 0575/2026

APPENDIX

Application/Limitation

Certificate no.:
MEDB0000B0Y
Revision no.:
0

The equipment is found to comply with following location/application dependent requirements
(for definition of each of the location classes, see below the table):

MODEL	TEMPERATURE	VIBRATION	EMC	ENCLOSURE
LOA	TEM-B	VIB-B	EMC-B	ENC-A (IP 40)
LOTA	TEM-B	VIB-B	EMC-B	ENC-A (IP 40)
LOTAI	TEM-D	VIB-B	EMC-B	ENC-A (IP 40)
LOTCA	TEM-A	VIB-B	EMC-B	ENC-A (IP 40)
OC-OIEX	TEM-C	VIB-B	EMC-B	ENC-A (IP 32)

Definition of the location classes with reference to relevant standards:

Definition of the location classes with reference to relevant standards:

- Temperature: TEM-A – Location (5°C-55°C) (ref. IEC 60092-504:2016 table 1 item 6-7)
TEM-B – Location (5°C-70°C) (ref. IEC 60092-504:2016 table 1 item 6-7)
TEM-C – Location (-25°C-55°C) (ref. IEC 60092-504:2016 table 1 item 6-7)
TEM-D – Location (-25°C-70°C) (ref. IEC 60092-504:2016 table 1 item 6-7)
- Vibration: VIB-B – For eq. on reciprocating machines etc. (ref. IEC 60092-504:2016 table 1 item 10)
- EMC: EMC-B – Bridge and open deck zone (ref. IEC 60092-504:2016 table 1 item 13-20)
- Enclosure: ENC-A – Control room, accommodation, bridge (ref. IEC 60092-201:1994 table 5)

Ex installations to be approved in each case according to the Rules and Ex-Certification/ Special Condition for Safe Use listed in valid Ex-certificate issued by a notified/recognized Certification Body.

Ex-certification is not covered by this certificate and the following paragraph, which is for information only, is based on information received from the manufacturer, but not verified by DNV.

Information on Ex-Certification received from manufacturer – Not verified by DNV		
Equipment	Certified	Certificate No.
OC-OIEX	Ex II 1G Ex ia IIC T6 Ga	LCIE 15 ATEX 3022X