

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate no.:
MEDB0000BKS
Revision no.:
0

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV AS under the authority of the Government of Norway.

This is to certify:

that the **A' & 'B' Class divisions fire integrity: - 'B' class division**

with type designation(s)
B25M(I) B-15 class bulkead panel

issued to

Huanan Building Materials (Shenzhen) Co., Ltd.
1002, Chiwan Tower, No.8, Chiwan 6th Road, Chiwan Community ,Zhaoshang Subdistrict,
Nanshan District, Shenzhen 518068 Guangdong China,

is found to comply with the Implementing Regulation (EU) 2025/1533 for
Item no. **MED/3.11b** (Row 1 of 1)

according to the following requirements:


SOLAS 74 Reg. II-2/9, IMO MSC.1/Circ.1581, SOLAS 74 Reg. II-2/3.4, IMO MSC/Circ.1120

Further details of the equipment and conditions for certification are given overleaf.

Date of issue: **2026-03-16**

Expiry date: **2031-03-15**

DNV local unit:
China South NB



for **DNV AS**

Approval Engineer:
Nanna Martine Jacobsen

Notified Body
no.: **0575**

Christine Mydlak-Röder
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the Agreement between the United States of America and the EEA EFTA states on the mutual recognition of Certificates of Conformity for Marine Equipment signed 17 October 2005, and amended by Decision No 1/2023 dated August 21st, 2023.



The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV AS of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

'B25M(I) type B-15 Class Bulkhead'

is constructed from prefabricated panels designed with a sandwich type configuration. Each panel consists of a 25 mm mineral wool insulation 'Maritime Rockwool Slab' (density 120 kg/m³, manufactured by ROCKWOOL Firesafe Insulation (Guangdong)). The insulation is faced on both sides with 0.55 mm galvanized steel sheets, which are bonded to the core using adhesive.

Total panel thickness: 25 mm

Panel to panel connection is achieved using 0.475 mm galvanized steel M profiles fixed along the longitudinal edges of the panels, in combination with 3 mm thick spline joints.

For further details see the drawings listed under Type Examination documentation below.

Application/Limitation

Approved for use as a vertical fire retarding division of class B-15.

Maximum size of panel: 650 mm x 2970 mm (W X L)

The insulation materials and adhesives used have to be approved according to the Marine Equipment Directive and bear the Mark of Conformity. This requirement may also be applicable for surface materials used, if required by relevant rules and regulations.

Each product is to be supplied with its manual for installation and maintenance.

Type Examination documentation

Tests carried out

IMO 2010 FTP Code part 3

Marking of product

The product is to be marked with name and address of manufacturer, type designation, fire technical rating, Mark of Conformity and USCG approval (see first page).