

TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate No:
MERB00009CB
Revision No:
0

This Certificate is issued by DNV UK Limited based on authorisation of the Maritime & Coast Guard Agency (MCA) as an UK Approved Body to undertake conformity assessments on marine equipment in accordance with the requirements of the Merchant Shipping (Marine Equipment) Regulations 2016 as amended.

This is to certify:

That the Portable fire extinguishers

with type designation(s)
Jockel K5J

Issued to

Feuerschutz Jockel GmbH & Co. KG
REMSCHIED, Germany

is found to comply with the requirements in the following Regulations/Standards:

Regulation ,

(UK) MSN 1874 Amendment 10,

item No. UK/3.2. SOLAS 74 as amended, Regulation II-2/4, II-2/10, II-2/18, II-2/19, II-2/20 & X/3, IMO Res.

A.951(23), 2000 HSC Code 7, FSS Code 4, IGF Code 11, IMO MSC.1/Circ.1239 and IMO MSC.1/Circ.1275

Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2030-08-10**.

Issued at **London** on **2025-08-11**

DNV local unit:
Essen



for **DNV UK Ltd.**

Approval Engineer:
Helge Bjørnara

Approved Body No.: **0097**

.....
Christine Mydlak-Röder
MER Service Responsible



**Maritime &
Coastguard
Agency**

UK Approved Body Authorised
by the MCA

This certificate will not be valid if the manufacturer makes any changes or modifications to the approved type of equipment, which have not been notified to, and agreed with the approved body named on this certificate.

During the period of validity of this certificate the applicable regulations (international conventions and the relevant resolutions and circulars of the IMO) and testing standards may change, therefore the product conformity may need to be re-assessed by the Approved Body.

"The Mark of Conformity" may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-control phase module (D, E or F) of Schedule 2 of the Merchant Shipping (Marine Equipment) Regulations 2016, as amended is fully complied with and controlled by a written inspection agreement with an approved body. In case limitations of use apply, these should be indicated in the Annex.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.

Product description

"Jockel K5J",
portable carbon dioxide fire extinguishers of size 5 kg.

Type	Fire rating	Temperature range [°C]	Extinguishing medium	Charge size	Assembly drawing No.
Jockel K5J	89B	-30 to +60	CO ₂	5 kg	RH30356

Application/Limitation

Approved for use as a portable carbon dioxide fire extinguisher.

Cylinder is to be PED approved and marked accordingly.

Each product is to be supplied with its manual for installation, use and maintenance.

Type Examination documentation

Type	Manual	Test reports	Test reports
		EN 3-7:2004 A1:2007	EN 3-9:2006 +A1:2007
Jockel K5J	Installation, Operation and Maintenance Manual	20200583/J 664 04-6-1671/J 210 2010-F-3562/J 387 20190889/J 655	20190889/J 658 20200583/J 684

Tests carried out

Tested according to EN 3-7:2004+A1:2007 and EN 3-9:2006+A1:2007.

Marking of product

The product is to be marked with name and address of manufacturer, type designation, the Mark of Conformity (see first page) and in accordance with EN 3-7, Ch.16.2 and EN 3-9, Ch.8.