



EUROPEAN UNION RECOGNISED ORGANISATION (EU RO) MUTUAL RECOGNITION TYPE APPROVAL CERTIFICATE

Certificate No:
MRA000004J

In accordance with Article 10.1 of EU Regulation 391/2009

This Certificate is issued to

KEUMYANG IND. CO., LTD.
Busan, Korea, Republic of

for

Temperature Gauges/Sensors/Transmitters

with type designation(s)

TTLTD - Temperature Sensor and Transmitter with Local Display

The product is found to comply with

EU RO Mutual Recognition Technical Requirements for Temperature Gauges and Transmitters

Intended service

Temperature transmitter intended for use in alarm and monitoring systems subject to classification.

Temperature [°C]: 5°C ~ 70°C

Vibration: ±1.6 mm / 4.0 g

EMC: General power distribution zone

IP Code: IP65

This is to certify:

that the Product referred to herein has been inspected for the Manufacturer, pursuant to the relevant requirements of the European Union Recognised Organisation Mutual Recognition procedure, required by Article 10.1 of EU Regulation 391/2009, and has been found in accordance with those requirements.

This Certificate is valid until **2029-11-10**.

Issued at **Høvik** on **2024-11-11**

DNV local unit: **Gimhae Station**

for **DNV**

Approval Engineer: **Nikolai Arntzen**

.....
Frederik Tore Elter
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: MRTA 201

Revision: 2022-12

www.dnv.com

Page 1 of 4

Product description

Temperature Sensor and Transmitter with Local Display – TTLD

Type Selection: KY-TI-X¹-X²-X³-X⁴-X⁵-X⁶-X⁷

TYPE X ¹
A

SENSOR X ²	
TC	RTD
J	PT 50Ω
K	PT 100Ω
E	PT 200Ω
T	PT 500Ω
B	PT 1000Ω
R	PT 10000Ω

POWER X ³	
1	LOOP POWER

INPUT X ⁴
0 ~ 600°C

OUTPUT X ⁵
4 ~ 20mA

L1 - LENGTH X ⁶

L2 - LENGTH X ⁷

Technical data

Display range	-1999...0...1999°C
Display character heights	25.4mm
Ambient temperature	-20...70°C
Degree of protection	IP65
Material of case	Aluminium

Electrical data

Accuracy	FSO ±1% of range ±1 digit
Loop power	18 ~ 36Vdc/voltage range

Analog output

Scaling	Measuring range
Signal error	Error signal according to NAMUR NE43
Load resistance	Max.500 Ω

Manufactured by

KEUMYANG Ind. Co., Ltd.
65-1, Jwadong-ro, Haeundae-gu,
Busan, Korea

Application/Limitation

The Type Approval covers only the transmitter with local display, not the sensor listed under Product description.

When the transmitter with local display is used in applications subject to class approval, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case.

Type Approval documentation

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Other Conditions

The temperature transmitters have been verified for compliance with EU Mutual Recognition Technical Requirements for Temperature Gauges and Transmitters version 4, dated 2024-07-01, including the Technical Requirements for Sensors version 0.6, dated 2025-01-01.

Tests carried out:

- Combined test 70°C at $\pm 10.0g$ for 4 hours.
- Combined test 75°C / 80°C / 85°C at $\pm 10.0g$ for 8 hours.
- Function check at 100°C, 300°C and 500°C.

Environmental test parameters

Temperature: 5°C and 70°C

Vibration: $\pm 1.6 \text{ mm} / 4.0 \text{ g}$

Humidity: 95%RH @ 55°C, damp heat cyclic

EMC: All locations except bridge and open deck

Enclosure: IP65 (IP-ratings according to IEC 60529)

DNV location classes

B

B

B

A

B

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE

Generic Statement for EU RO MR Type Approval Certificate

When a product is presented with this EU RO MR Type Approval Certificate for given application, its acceptability with regards to the limitations stated in the certificate conditions defined in 1b, 1c and 1d of the applied Technical Requirement will be evaluated by the EU RO in charge of classing the ship or being in charge of the unit/system certification.

In accordance with Article 10 of Regulation (EC) No 391/2009 of the European Parliament and of the Council of 23 April 2009 "on common rules and standards for ship inspection and survey organizations", the following organizations, recognized by the EU on this date, have agreed on the technical and procedural conditions under which they will mutually recognize this certificate:

- American Bureau of Shipping (ABS);
- Bureau Veritas (BV);
- China Classification Society (CCS);
- Croatian Register of Shipping (CRS);
- DNV;
- Indian Register of Shipping (IRS);
- Korean Register (KR);
- Lloyd's Register Group Ltd. (LR);
- Nippon Kaiji Kyokai General Incorporated Foundation (ClassNK);
- Polish Register of Shipping (PRS);
- RINA Services S.p.A. (RINA).

The scheme for the mutual recognition of class certificates for materials, equipment and components laid down by Article 10(1) of Regulation (EC) No 391/2009 is only enforceable within the Union in respect of ships flying the flag of a Member State. As far as foreign vessels are concerned, the acceptance of relevant certificates remains at the discretion of relevant non-EU flag States in the exercise of their exclusive jurisdiction, notably under the United Nations Convention on the Law of the Sea (UNCLOS). (In accordance with COMMISSION IMPLEMENTING REGULATION (EU) No 1355/2014 amending Regulation (EC) No 391/2009 - recital (25)).