

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Fire Alarm Manual Call Point**

with type designation(s)

Discovery Part No 58100-975MAR / 976MAR,**Discovery Part No 58100-970MAR / 971MAR**

Issued to

Apollo Fire Detectors Limited**HAVANT HAMPSHIRE, United Kingdom**

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Location classes:**

Type	Temp.	Humidity	Vibration	EMC	Enclosure
Discovery Part No 58100-975MAR / 976MAR	D	B	A	B	C (IP67)
Discovery Part No 58100-970MAR / 971MAR	D	B	A	B	B

This Certificate is valid until **2021-12-31**.Issued at **Høvik** on **2016-12-20**DNV GL local station: **London**for **DNV GL**Approval Engineer: **Nils Jarem**

.....

Odd Magne Nesvåg
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

Job Id:
Certificate No: **TAA00000WE**

Product description

Discovery Manual Call Points covered by this Type Approval:

Model	Description
58100-970MAR	Non-isolated red Manual Call Point, indoor use
58100-971MAR	Isolated red Manual Call Point, indoor use
58100-975MAR	Non-isolated red Manual Call Point, outdoor use
58100-976MAR	Isolated red Manual Call Point, outdoor use

Application/Limitation

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

To provide additional protection against accidental operation, a transparent hinged cover with a locking tag, part no 26729-152, is available. Please note that the manual call points (58100-970MAR/971MAR/975MAR/976MAR) do not conform to EN54-11 (2001) when this lid is fitted and secured with the locking tag supplied.

Not for application in hazardous areas

Type Approval documentation

Tests carried out

Applicable tests according to DNV Standard for Certification No. 2.4.

Type designations: 58100-970MAR, 58100-971MAR, 58100-975MAR, 58100-976MAR tested according to EN54-11 (2001) and EN54-17 (2005).

Job Id:
Certificate No: **TAA00000WE**

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE