DNV·GL

Certificate No:
TAA00000Y8

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Temperature Switch

with type designation(s)
RT-3, RT-9, RT-10, RT-13, RT-101, RT-106, RT-107, RT-120, RT-123, RT-124

Issued to
Danfoss A/S
NORDBORG, Denmark

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Location classes:

Type	Temperature	Humidity	Vibration	EMC	Enclosure
RT-3, RT-9, RT-10, RT-13	B	B	A	Not relevant	B/IP66
RT-101, RT-106, RT-107, RT-120, RT-123, RT-124	D	B	B	Not relevant	B/IP66

This Certificate is valid until **2022-05-01**.

Issued at **Høvik** on **2017-01-12**

for **DNV GL**

DNV GL local station: **Fredericia**

Approval Engineer: **Nils Jarem**

Odd Magne Nesvåg
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Job Id:
Certificate No: **TAA00000Y8**

Product description

The temperature-controlled switches:

Type:	Range [°C]:	Switching diff. [°C] at: min. setting /	max. setting
RT 3	-25 to 15	2.8 to 10	1 to 4
RT 9	-45 to -15	2.2 to 10	1 to 4.5
RT 10	-60 to -25	1.7 to 7	1 to 3
RT 13	-30 to 0	1.5 to 6	1 to 3
RT 101	25 to 90	2.4 to 10	3.5 to 20
RT 106	20 to 90	4 to 90	2 to 7
RT 107	70 to 150	6 to 25	1.8 to 8
RT 120	120 to 215	7 to 30	1.9 to 9
RT 123	150 to 250	6.5 to 30	1.8 to 9
RT 124	200 to 300	5 to 25	2.5 to 10

Output: 1 c/o contact
Contact load: AC-1: 10A, 400V; AC-3: 4A, 400V; AC-15: 3A, 400V

Place of manufacture

Danfoss Sp.z.o.o.
PL-05-825 Grodzisk Mazowiecki
Poland

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Application/Limitation

Thermometer wells shall be used when measuring temperature in fluids, steam or gases under pressure. RT-124 is not for application where DNV GL requires temperature wells.

All models to be equipped with metal cable entry, code No. 631-4547, and seal cap code No. 017-0895.

Type Approval documentation

Tests carried out

Applicable tests according to Standard for Certification No. 2.4, April 2006 and
Guidelines for the Performance of Type Approvals, Chapter 2 - Edition 2003

Marking of product

The products to be marked with:
- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:
- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)

- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE