

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Programmable Electronic System**with type designation(s)
Nexto Series

Issued to

ALTUS SISTEMAS DE AUTOMACAO S/A
São Leopoldo RS, Brazil

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Location classes:**

Temperature	B
Humidity	B
Vibration	A
EMC	B
Enclosure	A

Issued at **Hamburg** on **2017-04-24**This Certificate is valid until **2022-04-23**.for **DNV GL**DNV GL local station: **Approval Centre Brazil**Approval Engineer: **Dariusz Lesniewski**

.....

Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

Nexto Series Programmable Electronic System

Including:

CPUs – Central Processing Units

- NX3004: CPU with 1 Ethernet port, 1 serial channel, remote rack expansion support and integrated power supply
- NX3005: CPU with 1 Ethernet port, 1 serial channel, remote rack expansion support, power supply integrated and user web pages support
- NX3020: High-speed CPU, 2 Ethernet ports, 2 serial channels, memory card interface and remote rack expansion support
- NX3030: High-speed CPU, 2 Ethernet ports, 2 serial channels, memory card interface, remote rack expansion and redundancy support

Fieldbus Interfaces

- NX5000: Ethernet Module
- NX5001: PROFIBUS-DP Master

Power Supply Modules

- NX8000: 30 W 24 Vdc Power Supply Module

Racks

- NX9000: 8-Slot Backplane Rack
- NX9001: 12-Slot Backplane Rack
- NX9002: 16-Slot Backplane Rack
- NX9003: 24-Slot Backplane Rack

Accessories

- NX9100: Left/Right Side Rack Ends
- NX9101: 8 GB microSD memory card with miniSD and SD adapters
- NX9102: Rack Connector Cover
- NX9401: 6-Terminal Connector
- NX9404: 6-Terminal Connector with fixing

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Product certificate

If specified in the Rules, ref. Pt.4 Ch.9 Sec.1, the control and monitoring system in which the above listed hardware is used shall be delivered with a product certificate. For each such delivery the certification test is to be performed at the manufacturer of the application system before the system is shipped to the yard. The test shall be done according to an approved test program. After certification the clause for software control will be put into force.

Application/Limitation

- Installation in metallic cabinet only.
- The 24 Vdc power supply port shall be equipped with a power filter TDK-Lambda model RSMN-2003 or equivalent (reference is made to the document TDK-Lambda RSMN Series 002-02/20081120/etl_rsmn)
- For bridge installation the minimum compass safe distance of 5 m to be ensured.

Type Approval documentation

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, November 2016.

Marking of product

The products to be marked with:
- manufacturer name

Job Id: **262.1-019787-1**
Certificate No: **TAA000013D**

- model name
- serial number

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed at least every second year and at renewal of this certificate.

END OF CERTIFICATE