

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Level Switches**

with type designation(s)
003H0, 003H2, 003H5, 003S0, 003S2, 003S5

Issued to

Rosemount Measurement Limited
SLOUGH, BERKSHIRE, United Kingdom

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Location classes:

Temperature	B
Humidity	B
Vibration	A
EMC	A
Enclosure	C / IP66,
	D / IP68 (3m)

Issued at **Høvik** on **2017-03-14**

This Certificate is valid until **2021-11-01**.

DNV GL local station: **Southampton**

Approval Engineer: **Ståle Sneen**

for **DNV GL**

.....
Odd Magne Nesvåg
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

Mobrey 003 ultrasonic liquid level switch models 003H0, 003H2, 003H5, 003S0, 003S2 and 003S5.

Code 003:	Integral ultrasonic level sensor, polyphenylene sulphide construction
Code Output type:	S = Integral SPCO relay (energised when sensor wet) H = Two open-drain FET transistors (one conducting when sensor wet, one conducting when sensor dry)
Code Mounting thread:	0 = 3/4" BSPT dual 2 = 1" BSPT dual 5 = 1" NPT dual
Power supply:	24 V AC or DC
Operating pressure:	5 bar
Maximum switched current:	1A at 30V resistive, 0.25A at 30V inductive (type S) 100mA max. (type H)
Maximum switched voltage:	30V
Electrical connection:	fixed 3 core-cable, cable length 50m max., type: 3x0.75mm ² (Habia cable, drawing no. 700051572)
Media:	non-flammable liquids

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Type Approval documentation

Tests carried out

Guidelines for the Performance of Type Approvals, Chapter 2, Edition 2003

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Job Id: **262.1-024172-1**
Certificate No: **TAA0000140**

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE