

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Pressure Transmitter

with type designation(s)
JUMO MIDAS S07 MA (Type 401021)

Issued to

JUMO GmbH & Co. KG
Fulda, Hessen, Germany

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Temperature	B
Humidity	B
Vibration	A
EMC	A
Enclosure	A/B* see Product Description

Issued at **Hamburg** on **2017-12-29**

This Certificate is valid until **2022-12-28**.

DNV GL local station: **Magdeburg**

Approval Engineer: **Jens Dietrich**

for **DNV GL**

.....
Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

The MIDAS S07 MA pressure transmitter is used for measuring pressure in gases and liquids.

Output signal / Voltage supply: 4 ... 20mA, 2-wire / 10 ... 25V DC

0 ... 10V DC, 3-wire / 15 ... 25V DC

1 ... 5V DC, 3-wire / 10 ... 25V DC

1 ... 6V DC, 3-wire / 10 ... 25V DC

Measuring range: -1 ... 100bar relative pressure, and also up to 0 ... 25bar absolute pressure

Process connection material: CrNi (stainless steel)

Electrical connection / *Protection type:

Attached cable / IP66

Plug M12x1 / IP66

Plug connector / IP30

Cable socket / IP65

Application/Limitation

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL RU SHIP Pt. 4 Ch. 9 Sec. 1.

Tests carried out

Applicable Tests according to Class Guideline DNV GL CG-0339, November 2016

Marking of product

Maker, type, serial-number

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of this certificate.

END OF CERTIFICATE