DNV·GL

Certificate No:
TAA00001JY

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Level Transmitter

with type designation(s)
Level Transmitter XTL458,
Pressure Transmitters XTP457, XTP457-SOL, XTK457, XTK458

Issued to
XTronica AS
Flatåsen, Norway

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Location classes:

Temperature	**D**
Humidity	**B**
Vibration	**B**
EMC	**B**
Enclosure	**D***

***See Application/Limitation**

Issued at **Høvik** on **2018-01-19**
This Certificate is valid until **2022-12-31**.
DNV GL local station: **Trondheim**

Approval Engineer: **Nils Jarem**

for **DNV GL**

Odd Magne Nesvåg
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Job Id: **262.1-011021-4**
Certificate No: **TAA00001JY**

Product description
Level Transmitters: XTL458
Pressure Transmitters: XTP457, XTK457, XTK458, XTP457-SOL

Place of manufacture
BD SENSORS s.r.o.
Hradistska 817
CZ-68708 Buchlovice, Czech Republic

BD SENSORS GmbH
BD-Sensors-Str.1
95199 Thierstein
Germany

Approval conditions
The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Application/Limitation
Ex-certification is not covered by this certificate.

The transmitters might also be delivered with another cable gland. The enclosure class of the transmitter will depend then on the mounting method and IP rating of the cable gland.

Type Approval documentation

Tests carried out
Applicable tests according to Standard for Certification No. 2.4, April 2006.

Marking of product
Manufacturer: XTronica
Model name: As listed under Product description
Serial number: Unique for each delievered item

Periodical assessment
The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:
- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE

Job Id: **262.1-011021-4**
Certificate No: **TAA00001JY**