

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Programmable Controller**with type designation(s)
CR0032, CR0232, CR0234, CR7032, CR7132

Issued to

IFM Electronic GmbH
Essen, Germanyis found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Location classes:**

Temperature	D
Humidity	B
Vibration	B
EMC	B
Enclosure	C

Issued at **Hamburg** on **2018-05-30**This Certificate is valid until **2023-05-29**.for **DNV GL**DNV GL local station: **Augsburg**Approval Engineer: **Dariusz Lesniewski**

Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

Mobile controller series CR0xxx

- 32-bit CPU Infineon TriCore 1796
- Memory: Flash 2 Mbytes, RAM 2 Mbytes, Remanent memory 128 Kbytes
- 4 CAN interfaces
- Serial interface RS-232-C
- USB Virtual COM Port
- CODESYS 2.3 programming system
- Status LED (R/G/B)
- Operating voltage: 10...32 V DC / 8...32 V DC for CR0234 (see limitation)
- Inputs/Outputs:

CR0032

- 16 inputs configurable: digital, analogue, frequency
- 16 outputs configurable: digital, PWM output, current-controlled

CR0232

- 32 inputs configurable: digital, analogue, frequency
- 48 outputs configurable: digital, PWM output, current-controlled

CR0234

- 32 inputs configurable: digital, analogue, frequency
- 48 outputs configurable: digital, PWM output, current-controlled

Safety controller series CR7xxx

- 32-bit CPU Infineon TriCore 1796
- Memory: Flash 4 Mbytes, RAM 2 Mbytes, Remanent memory 128 Kbytes
- 2 CANsafety interfaces
- Serial interface RS-232-C
- USB Virtual COM Port
- CODESYS 2.3 programming system
- Status LED (R/G/B)
- Operating voltage: 8...32 V DC (see limitation)
- Inputs/Outputs:

CR7032

- 16 inputs configurable, safety-related: digital, analogue, frequency
- 16 outputs configurable, safety-related: digital, PWM output, current-controlled

CR7132

- 32 inputs configurable, safety-related: digital, analogue, frequency
- 48 outputs configurable, safety-related: digital, PWM output, current-controlled

Module/Unit	Software Number/Version
CR0032	V02.01.xx / V03.00.xx
CR0232	V01.00.xx
CR0234	V01.00.xx
CR7032	V01.00.xx
CR7132	V01.00.xx

Place of manufacture

ifm ecomatic gmbh
Im Heidach 18
88079 Kressbronn (GER)

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for

Job Id: **262.1-024263-1**
Certificate No: **TAA00001S2**

approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Product certificate

If specified in the Rules, ref. Pt.4 Ch.9 Sec.1, the control and monitoring system in which the above listed hardware is used shall be delivered with a product certificate. For each such delivery the certification test is to be performed at the manufacturer of the application system before the system is shipped to the yard. The test shall be done according to an approved test program. After certification the clause for software control will be put into force.

Software control

All changes in software are to be recorded as long as the system is in use on board. Documentation of major changes is to be forwarded to DNV GL for evaluation and approval before implemented on board. Certification of modified functionality may be required for the particular vessel.

Application/Limitation

Controllers to be powered by one of the following power supply units:
QS40.244 (PULS GmbH) or QUINTPS/ 1AC/24DC/40 (Phoenix Contact)

Type Approval documentation

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, November 2016.

Marking of product

The products to be marked with:

- manufacturer name
- model name
- product code
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed at least every second year and at renewal of this certificate.

END OF CERTIFICATE