DNV·GL

Certificate No:
TAA00001UN

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Pressure Transmitter

with type designation(s)
AT9000 Advanced Transmitter Model GTX

Issued to
Azbil Corporation
Fujisawa, Kanagawa Pref., Japan

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Location classes:

Temperature	**D**
Humidity	**B**
Vibration	**A**
EMC	**B**
Enclosure	**C (IP67)**

Issued at **Høvik** on **2018-05-18**
This Certificate is valid until **2020-06-30**.
DNV GL local station: **Yokohama**

for **DNV GL**

Approval Engineer: **Ståle Sneen**

Odd Magne Nesvåg
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Job Id: **262.1-009058-5**
Certificate No: **TAA00001UN**

Product description
Microprocessor-based AT9000 Pressure Transmitter Model GTX.
Power supply: 24 V DC (17.9 V – 42 V)
Output: 4-20 mA DC

Place of manufacture
Azbil Corporation,
4-1-1 Omagari, Samukawa-machi, Koza-gun,
Kanagawa Pref. 253-0113 Japan

Approval conditions
The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Application/Limitation
Ex-certification is not covered by this certificate. Application in hazardous area to be approved in each case according to the Rules and Ex-Certification/ Special Condition for Safe Use listed in valid Ex-certificate issued by a notified/recognized Certification Body.

Type Approval documentation

Tests carried out
Applicable tests according to class guideline DNVGL-CG-0339, November 2016.
Cold test performed for 16h at -40°C.

Marking of product
The products to be marked with:
- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE