DNV·GL

Certificate No:
TAA0000211

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Pressure Transmitter

with type designation(s)
MIDAS C18 SW (Type 401012)

Issued to
JUMO GmbH & Co. KG
Fulda, Hessen, Germany

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Temperature	**D (tested 85°C)**
Humidity	**B**
Vibration	**B**
EMC	**B**
Enclosure	**B (IP65/67)**

Issued at **Hamburg** on **2018-09-17**
This Certificate is valid until **2023-09-16**.
DNV GL local station: **Hamburg**

Approval Engineer: **Jens Dietrich**

for **DNV GL**

Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Job Id: **262.1-027058-1**
Certificate No: **TAA0000211**

Product description

Pressure transmitter with impervious and hysteresis-free ceramic measuring cell, a titanium case, and a titanium process connection.

Measuring ranges are available in the range of -1.0bar up to 100bar.
Signal output: 4mA to 20mA (two-wire) and DC 0V to10V (three-wire),
Jump response time t_{90}: ≤2ms.
Electrical connections:
Round plug M12 (connection 36) or Cable socket (connection 61).
Voltage supply:
4mA to2 0mA, two-wire (output 405) 10V to 30VDC, rated voltage supply 24VDC
0 to10V DC, three-wire (output 415) 11.5V to30VDC, rated voltage supply 24VDC.
Burden:
Current RL≤(UB-8V)÷0.02A(Ω) for 4 to 20mA, two-wire (output 405),
Voltage RL≥10kΩ for DC0to10V, three-wire (output 415).

Degree of protection:
Type with round plug M12 (connection 36): IP67,
Type with cable socket (connection 61): IP65.

Vibration withstand according to IEC60068-2-6: 20g, 15…2000Hz.

Application/Limitation

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL Rules for Ships Pt.4 Ch.9 Control and Monitoring Systems.

Tests carried out

Applicable tests according to Class Guideline DNVGL-CG-0339, Edition November 2016.

Marking of product

Maker, type and serial number.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of this certificate.

END OF CERTIFICATE