

# TYPE APPROVAL CERTIFICATE

**This is to certify:****That the Level Control System**

with type designation(s)

**AFV-MG-GL, ARV-MG-GL, NMG 125-GL, FLR-SAG, FLR-SAGI, FLR-SBG, FLR-SBGI, FLR-SFG**

Issued to

**KSR Kuebler Niveau-Messtechnik AG**  
**Zwingenberg, Germany**

is found to comply with

**DNV GL rules for classification – Ships, offshore units, and high speed and light craft****Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Location classes:**

|                    |          |
|--------------------|----------|
| <b>Temperature</b> | <b>C</b> |
| <b>Humidity</b>    | <b>B</b> |
| <b>Vibration</b>   | <b>A</b> |
| <b>EMC</b>         | <b>A</b> |
| <b>Enclosure</b>   | <b>C</b> |

Issued at **Hamburg** on **2019-08-28**This Certificate is valid until **2024-08-27**.DNV GL local station: **Augsburg**for **DNV GL**Approval Engineer: **Dariusz Lesniewski**

---

**Joannis Papanuskas**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



## Product description

AFV-MG-GL/..., FLR-SAG: Flange type with connection-box  
ARV-MG-GL/..., FLR-SAG: Threaded type with connection-box  
AFV-MG-GL/..., FLR-SBG: Flange type with connection-box and transmitter  
ARV-MG-GL/..., FLR-SBG: Threaded type with connection-box and transmitter  
AFV-MG-GL/..., FLR-SFG: Flange type with connector  
ARV-MG-GL/..., FLR-SFG: Threaded type with connector  
NMG-125-GL/..., FLR-SAGI : Ex type with connection-box  
NMG-125-GL/..., FLR-SBGI : Ex type with connection-box and transmitter

Output: resistor potentiometer chain 1kOhm to 100kOhm with/or without transmitter (T....)  
or with electronic unit (MD....)

Material rod and float: stainless steel or titanium

Float: ball or cylinder

Guide tube length: without holder up to 2500 mm.

If the guide tube is longer an additional holder has to be installed every 4000 mm.

Rated pressure: max. 40 bar

Media temperature: max: 150 °C

Degree of protection: IP 65

Certified safe type (NMG 125-GL, FLR-SxGI): see certificate KEMA 01 ATEX 1052X

## Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Ex-certification is not covered by this certificate. Application in hazardous area to be approved in each case according to DNV GL Rules and Ex-Certification / Special Condition for Safe Use listed in valid Ex-certificate issued by a notified/recognized Certification Body.

## Type Approval documentation

### Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, November 2016.

### Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

### Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications



Job Id: **262.1-030425-1**  
Certificate No: **TAA00002F7**

- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE