DNV·GL

Certificate No:
TAA00002H9

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Loop-powered isolators

with type designation(s)
ProLine P224xxP1

Issued to
Knick Elektronische Messgeräte GmbH & Co. KG
Berlin, Germany

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Location classes:

Temperature	**B**
Humidity	**B**
Vibration	**A**
EMC	**A**
Enclosure	**A**

Issued at **Hamburg** on **2019-10-22**
This Certificate is valid until **2024-10-21**.
DNV GL local station: **Magdeburg**

Approval Engineer: **Dariusz Lesniewski**

for **DNV GL**

Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Product description

Loop-powered isolators for transmitting 0(4)..20 mA standard signals with protective separation between input and output

ProLine P22401P1: Loop-powered isolators for standard signals, 1 channel
- Rating: Input: 0(4)…20 mA / max. 30.5 V
- Output: 0(4)…20 mA / max. 27.5 V (1375 @ at 20 mA)
- Insulation: Reinforced Insulation up to 600 V AC/DC across input and output with overvoltage category III (OVCIII)
- Reinforced Insulation up to 600 V AC/DC across all channels with overvoltage category II (OVCII)

ProLine P22402P1: Loop-powered isolators for standard signals, 2 channels
- Rating: Inputs: 0(4)…20 mA / max. 30.5 V
- Outputs: 0(4)…20 mA / max. 27.5 V (1375 @ at 20 mA)
- Insulation: Reinforced Insulation up to 600 V AC/DC across input and output with overvoltage category III (OVCIII)
- Reinforced Insulation up to 600 V AC/DC across all channels with overvoltage category II (OVCII)

ProLine P22412P1: Loop-powered splitter for standard signals, 2 channels
- Rating: Input: 0(4)…20 mA / max. 30.5 V
- Outputs: 0(4)…20 mA / total of max. 24 V for both channels
- Insulation: Reinforced Insulation up to 600 V AC/DC across input and output with overvoltage category III (OVCIII)
- Reinforced Insulation up to 600 V AC/DC across all channels with overvoltage category II (OVCII)

Ambient ratings for all models: pollution degree: PD2
Ambient temperature: -40 … +85 °C (-40 … 185 °F)
Degree of protection: IP20
Mounting: 35-mm DIN rail according to EN 60715

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Type Approval documentation

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, November 2016.

Marking of product

The products to be marked with:
- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:
- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)

- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE