

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Programmable Controller**with type designation(s)
FX3UC Series Programmable Controllers

Issued to

Mitsubishi Electric Corporation, Nagoya Works
Nagoya, AICHI, Japanis found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Temperature B****Humidity B****Vibration A****EMC A or B (When installed in metallic cabinet with noise filter and shielded cables)****Enclosure Required protection according to the Rules to be provided upon installation on**Issued at **Busan** on **2019-12-18**This Certificate is valid until **2024-12-09**.for **DNV GL**DNV GL local station: **Kobe**Approval Engineer: **Dong Ho Park**

Andreas Kristoffersen
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

FX3UC Series programmable controllers consists of the following components;

Base units:

FX3UC-16MT/D, FX3UC-16MT/DSS: 16 I/O points

FX3UC-32MT/D, FX3UC-32MT/DSS: 32 I/O points

FX3UC-64MT/D, FX3UC-64MT/DSS: 64 I/O points

FX3UC-96MT/D, FX3UC-96MT/DSS: 96 I/O points

...T/D: Input Signal 24V DC (Sink Type), Transistor Output (Sink Type)

...T/DSS: Input Signal 24V DC (Sink/Source Type),
Transistor Output (Source Type)

Extension Power Supply Unit: FX3UC-1PS-5V: 5V DC (max. 1 A)

Power supply: 24V DC

Requirement class: 3

Firmware version: 3.x

Application/Limitation

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Product certificate

If specified in the Rules, ref. Pt.4 Ch.9 Sec.1, the control and monitoring system in which the above listed hardware is used shall be delivered with a product certificate. For each such delivery the certification test is to be performed at the manufacturer of the application system before the system is shipped to the yard. The test shall be done according to an approved test program. After certification the clause for software control will be put into force.

Software control

All changes in software are to be recorded as long as the system is in use on board. Documentation of major changes is to be forwarded to DNV GL for evaluation and approval before implemented on board. Certification of modified functionality may be required for the particular vessel.

Safe distance to magnetic compass, >5m

Type Approval documentation

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, November 2016.

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available

Job Id: **262.1-032561-1**
Certificate No: **TAA00002K1**

- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE