

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Peripheral Equipment

with type designation(s)
WAGO I/O SYSTEM 750

Issued to

WAGO Kontakttechnik GmbH & Co. KG
Minden, Nordrhein-Westfalen, Germany

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Temperature B

Humidity A*

Vibration B

EMC B*

Enclosure Required protection according to the Rules shall be provided upon installation on board.

***see Application/Limitation**

Issued at **Hamburg** on **2020-03-17**

This Certificate is valid until **2025-03-16**.

DNV GL local station: **Hamburg CMC**

for **DNV GL**

Approval Engineer: **Heinz Scheffler**

.....
Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

The WAGO-I/O-SYSTEM 750 is a modular, fieldbus independent I/O system.

Analogue Input (AI) Modules

750-498	8-AI-Thermocouples
---------	--------------------

Application/Limitation

Location classes:

- EMC A: equipment that is to be installed more than 5 m from magnetic compass.
24V DC Power Supply Filter with Overvoltage is to be installed
- Humidity A: Locations where special precautions are taken to avoid condensation

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL Rules for Ships Pt.4 Ch.9 Control and Monitoring Systems.

Type Approval documentation

Test Report: 419.054.2A, dated 2020-01-22; 419.054.4, dated 2019-09-03; 419.054.5, dated 2019-09-03; K100410_P17-00598 Test report Tests according to DNVGL V20001, Rev. 2.0.2; K100410_P17-00598 HTS_MC004139_Prüfbericht_MessgenauigkeitsuntersuchungenV10000, Rev. 1.0.1; K100410_P17-00598_DOC_750-498_Funktionsfähigkeitsprüfung_(PFVP)_V10010, Rev. 1.0.1; Needle-flame test No. 20888, dated 2010-08-16

Tests carried out

Applicable tests according to Class Guideline DNVGL-CG-0339, Edition November 2016.

Marking of product

The products to be marked with:

- Model name
- Manufacturer name
- Serial number

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE