DNV·GL

Certificate No:
TAA00002M7

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Level Switches

with type designation(s)
SU-SLM3G-TF M18

Issued to
Taiyo Valve Mfg. Co., Ltd.
Ohta-ku, Tokyo, Japan

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Location classes:

Temperature	**B**
Humidity	**B**
Vibration	**B**
EMC	**A**
Enclosure	**B / IP67**

Issued at **Høvik** on **2020-02-03**
This Certificate is valid until **2025-02-02**.
DNV GL local station: **Yokohama**

Approval Engineer: **Ståle Sneen**

for **DNV GL**

Marta Alonso Pontes
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Job Id: **262.1-032959-1**
Certificate No: **TAA00002M7**

Product description

SU-SLM3G-TF M18 level switch:

Measuring principle:	Electrostatic capacitance
Fluid (liquid):	Oil
Fluid temperature:	Max. 105°C
Ambient temperature:	Max. 90°C
Fluid pressure:	Max. 2 MPa
Fitting method:	Screw M18 x 1.5
Power supply:	DC 12~24 V (nominal)
Output capacity:	Max. 0.5 A
Operation of contact:	terminal 3-4 – voltage on (at dry), or open circuit / high impedance (at wet)
Degree of protection:	IP67

Place of manufacture

Taiyo Valve Mfg. Co., Ltd. Shirakawa Works
Oshodan 18, Shirakawa City
Fukushima 961-0985, Japan

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Type Approval documentation

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, November 2016.
150% pneumatic and hydraulic pressure test (3 MPa for 1 minute).

Marking of product

The products to be marked with:
- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE