DNV·GL

Certificate No:
TAA00002SY

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Electrical Parameter Transmitter

with type designation(s)
LCOS-CC, LCOS-CC-I, LCOS-BC, LCOS-FT, LCOS-FTE, LCOS-FTZ

Issued to
Friedrich Lütze GmbH
Weinstadt, Germany

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Temperature	**D**
Humidity	**B**
Vibration	**A**
EMC	**B**
Enclosure	**A**

Issued at **Hamburg** on **2020-05-27**
This Certificate is valid until **2025-05-26**.
DNV GL local station: **Augsburg**

for **DNV GL**

Approval Engineer: **Jens Dietrich**

Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV GL AS, its parent companies and subsidiaries as well as their officers, directors and employees ("DNV GL") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Product description

Load Monitoring Modules
1- or 2 channel version, 24V DC, switching range DC 1A…10A or DC 2A…16A, characteristic adjustable, with (LCOS-CC) or without CANopen communication (LCOS-CC-I), Output MOSFET/Relay, DC10A or 16A, pluggable on Lütze function carriers LCOS-FT/E:

LCOS-CC-aa-bb-ccccc-dd**, LCOS-CC-I**-aa-bb-ccccc-dd

aa=1K: 1 load channel
aa=2K: 2 load channels

bb=1P: 1-pole switch output
bb=2P: 2-pole switch output

ccccc=DC24V

dd=empty: terminals
dd=PB: Powerbus, terminals

Function carriers for DIN-Rail mounting, 24VDC:

LCOS-FTE-aa-bbb-cccc-00-d-e,
LCOS-FTZ-aa-bbb-cccc-00-d-e,
LCOS-FT-aa-xxx-cccc-00-d-e

aa=PE: with PE connection
aa=NC: no PE connection

bbb=575: 57.5mm width
bbb=700: 70.0mm width
xxx=225: 22.5mm width
xxx=350: 35.0mm width

cccc=NC: no bus communication
cccc=PN: Profinet
cccc=EC: EtherCat
cccc=ETIP: Ethernet-IP
cccc=UN: Universal

d=1: colour pebble grey
d=2: colour traffic yellow
d=9: colour titanium grey

e=L: Lütze label
e=T: Turck label
e=S: Siemens label

Bus coupling modules (pluggable):

LCOS-BC-PN	Profinet
LCOS-BC-EC	EtherCat
LCOS-BC-ETIP	Ethernet-IP

Application/Limitation

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for

approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

LOCS-CC and LCOS-CC-I are no replacement for circuit protection.

Tests carried out

Applicable tests according to DNV GL CG-0339, December 2019.

Marking of product

Maker, Mat.-Nr., Type designation, electrical ratings, serial number.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE