DNV·GL

Certificate No:
TAA00002UC

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Peripheral Equipment

with type designation(s)
PSR-SCP-24DC/..., PSR-SPP-24DC/...

Issued to
Phoenix Contact GmbH & Co. KG
Blomberg, Nordrhein-Westfalen, Germany

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Temperature	**B**
Humidity	**B**
Vibration	**A**
EMC	**B**
Enclosure	**Required protection according to the Rules shall be provided upon installation on board.**

Issued at **Hamburg** on **2020-09-17**
This Certificate is valid until **2025-09-16**.
DNV GL local station: **Hamburg CMC**

Approval Engineer: **Heinz Scheffler**

for **DNV GL**

Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV GL AS, its parent companies and subsidiaries as well as their officers, directors and employees ("DNV GL") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Product description

SIL coupling relay

2981978: PSR-SCP-24DC/FSP/1X1/1X2
2981981: PSR-SPP-24DC/FSP/1X1/1X2
2986575: PSR-SCP-24DC/FSP2/2X1/1X2
2986588: PSR-SPP-24DC/FSP2/2X1/1X2
2986960: PSR-SCP-24DC/FSP/2X1/1X2
2986957: PSR-SPP 24DC/FSP/2X1/1X2

Connection type:
- SCP: with screw connection
- SPP: with spring-cage connection

Contact type …1X1/1X2:
- 1 undelayed enabling current path
- 1 undelayed confirmation current path

Contact type …2X1/1X2:
- 2 undelayed enabling current path
- 1 undelayed confirmation current path

Input data
- Nominal input voltage: 24V DC

Output data
- Max. switching voltage: 250V AC/DC
- Min. switching voltage: 15V AC/DC
- Min. switching current: 5mA
- Min. switching power: 75mW

Application/Limitation

SIL-certification is not covered by this certificate. SIL-Certification is listed in valid SIL-certificate Nr./No.: 968/EZ 365.05/16 & 968/EZ 365.06/16 issued by TÜVRheinland.

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case.
Reference is made to DNV GL Rules for Ships Pt.4 Ch.9 Control and Monitoring Systems.

Type Approval documentation

Test Reports U140359E1; E140359E1; E200581E1
Documents: TAA00002UC_Overview_Documents Rev.01; Data Sheet 104510_en_02; Data Sheet 104509_en_03; Data Sheet 104410_en_02

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, December 2019

Marking of product

The products to be marked with:

- Model name
- Manufacturer name
- Serial number

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE