DNV·GL

Certificate No:
TAA00002VK

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Pressure Switch

with type designation(s)
MDR-F..2, 4, 8, 10, 12.5, 16, 32, 60, 120, 250..

Issued to
Condor-Werke Gebr. Frede GmbH
Ennigerloh, Germany

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Temperature	**B**
Humidity	**B**
Vibration	**B**
EMC	**A**
Enclosure	**Required protection according to DNV GL Rules shall be provided upon installation on board**

Issued at **Hamburg** on **2020-10-01**
This Certificate is valid until **2025-09-30**.
DNV GL local station: **Magdeburg**

Approval Engineer: **Didier Girardin**

for **DNV GL**

Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV GL AS, its parent companies and subsidiaries as well as their officers, directors and employees ("DNV GL") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.

© DNV GL 2014. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

Product description

TECHNICAL DATA:
Rated operating current Ie, Ue=240V (1~)/AC 1 10A
Rated operating current Ie, Ue=240V (1~)/AC 15 4A
Output contacts:
Microswitch, 1x SPDT (Single Pole Double Throw)
Temperature range:
Metal Flange -20 °C...+70 °C
Plastic Flange -20 °C...+50 °C
Degree of Protection: IP65
Material Flange:
High pressure flange, CuZn39Pb3 (CW614N); CuZn36Pb2As (CW602N);
X10CrNiS189 (1.4305);
X2CrNiMoN22-5-3 (1.4462)
Metal flange, G-AlSi 12
Plastic flange, PA 6.6 GF 30%
Pressure range:
High pressure flange up to 250 [bar]
Metal flange up to [32 bar]; Plastic flange up to 12,5 [bar]

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Type Approval documentation

Hidden
Renewal of certificate 86884 -10 HH including:

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, December 2019.

Marking of product

The products to be marked with:
- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE