

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Flow Sensor**

with type designation(s)
SA4100, SA4300, SA5000

Issued to

IFM Electronic GmbH
Essen, Germany

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.

Location classes:

Temperature D
Humidity B
Vibration A, B*
EMC A
Enclosure B

***not for SA4300**

Issued at **Hamburg** on **2021-01-11**

This Certificate is valid until **2026-01-10**.

DNV GL local station: **Augsburg**

for **DNV GL**

Approval Engineer: **Dariusz Lesniewski**

.....
Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV GL AS, its parent companies and subsidiaries as well as their officers, directors and employees ("DNV GL") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

Flow sensor for monitoring of liquids and gases

Main device features:

- flow detection based on the calorimetric measuring principle
- displaying of the current process value (flow, temperature)
- generating of two output signals (selectable): switching signal for flow limit values, frequency signal for flow, switching signal for temperature limit values, analogue signal for flow, analogue signal for temperature, frequency signal for flow, frequency signal for temperature, input for external teach signal)
- IO-Link communication interface

Main device specification:

- Media: water, glycol solutions, air, oils
- Flow measuring range: 0.04...3 m/s for liquids, 2...100 m/s for gases
- Temperature measuring range: -20...100 °C
- Pressure max.: 50 bar SA4x00
- Pressure max.: 100 bar SA5000
- Power supply: 24V DC nom. (18V DC min. / 30V DC max.)
- Outputs: 2x digital (PNP/NPN switching signal, frequency signal, IO-LINK), 1x analogue (4...20mA)
- Display: alphanumeric display red/green 4-digit, 6 x LED green
- Programming buttons
- Connector: Mx12 with 2m cable (EVC001)
- Probe length/connection:
 - SA4100: 100 mm / by progressive ring fitting E40258 (Ø 8mm sensor / G½ process connection)
 - SA4300: 200 mm / by progressive ring fitting E40258 (Ø 8mm sensor / G½ process connection)
 - SA5000: 45 mm / threaded connection M18 x 1,5 internal thread
- Materials: stainless steel (1.3304 / 316L)
- Degree of protection: IP 44

Firmware version: V.074

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Type Approval documentation

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, December 2019.

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available

Job Id: **262.1-034349-1**
Certificate No: **TAA00002XV**

- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE