Certificate No:
TAA000031C

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Signal lamps

with type designation(s)
Signal Tower SL4-, SL7-series

Issued to
Eaton Industries GmbH
Bonn, Nordrhein-Westfalen, Germany

is found to comply with
DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Temperature	**D**
Humidity	**B**
Vibration	**A**
EMC	**A**
Enclosure	**B, IP66**

Issued at **Hamburg** on **2022-03-02**
This Certificate is valid until **2026-07-27**.
DNV local station: **Essen**

Approval Engineer: **Jens Dietrich**

for **DNV**

Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.

Product description

Signal Tower, Quick Installation base:
SL4-FMS-(a), SL7-FMS-(a)
(a)=**100**: 100mm base height for conventional wiring.

Signal Tower, Continuous light modules different colours:
SL4-L-(a), SL7-L-(a)
(a)=**B** (blue), **G** (green), **R** (red), **W** (clear), **Y** (yellow), **A** (amber) Signal Tower, LED light modules

LED light modules:

SL4-(a)-(b)-(c)-(d)
(a)=**L** (continuous light), **BL** (flashing light), **FL** (strobe light);
(b)=Operating voltage: **24** (24 AC/DC), **120** (110/120VAC), **230** (230/240VAC);
(c)=**B** (blue), **G** (green), **R** (red), W (clear), **Y** (yellow), **A** (amber);
(d)=blank (single strobe), **M** (Multi-strobe, only with (a) type FL24).

SL7-(a)-(b)-(c)-(d)
(a)=**L** (continuous light), **BL** (flashing light), **FL** (strobe light);
(b)=Operating voltage: **24** (24 AC/DC), **120** (110/120VAC), **230** (230/240VAC);
(c)=**B** (blue), **G** (green), **R** (red), W (clear), **Y** (yellow), **A** (amber);
(d)=blank (single strobe), **HP** (High performance LED), **HPM** (High performance LED, multi-strobe light).

Signal Tower, Acoustic Indicator Module (continuous or pulsed tones):
SL4-AP-(a), SL7-AP-(a)(b)
(a)=Operating voltage: **24** (24V AC/DC), **120** (110/120V AC), **230** (230/240V AC).
(b)=**E**: Can be externally actuated, (b)=**M**: 8 types of sound via 3-pole DIP-switch.

Signal Tower accessories:
SL7/4-FW-T: Metal bracket including M20 cable gland
SL7/4-FW: Plastic bracket vertical mounting.

Degree of Protection: IP66.

Approval conditions
The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV / DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Application/Limitation
Limited number of 4 modules to be stacked on one base.

Tests carried out
Applicable tests according to DNV GL CG-0339, August 2021.

Marking of product
Sticker with manufacturer name, type designation, electrical ratings, production lot.

Periodical assessment
The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:
- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE