Certificate No:
TAA000031D

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Electric protection and measuring relay

with type designation(s)
Thermistor Protection Relays EMT6 series, Electronic Timing Relays ETR4 series

Issued to
Eaton Industries GmbH
Bonn, **Germany**

is found to comply with
DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Type	Temperature	Humidity	Vibration	EMC	Enclosure
Thermistor Protection Relays EMT6 series	**B**	**B**	**A**	**B**	**A**
Electronic Timing Relays ETR4 series	**B**	**B**	**A**	**A**	**A**

Issued at **Hamburg** on **2023-03-24**
This Certificate is valid until **2027-07-03**.
DNV local station: **Essen**

Approval Engineer: **Jens Dietrich**

for **DNV**

Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.

Product description

Thermistor Overload Relays EMT6 series (Ith: 6A, Ie: 3A)
EMT6 (Art.66166): Thermistor protection, auto reset, 24–240 V AC/DC

EMT6-DB (Art.66167): same as EMT6, plus manual/auto reset, remote reset, fault memory

EMT6-DBK (Art.66168): same as EMT6-KDB, plus undervoltage protection

EMT6(230V) (Art.66400): Thermistor protection, auto reset, 230V AC

EMT6-DB (230V) (Art.66401): same as EMT6 (230 V), plus manual/auto reset, remote reset, fault memory

EMT6-K (Art.269470): same as EMT6, plus short-circuit monitoring EMT6-K

EMT6-KDB (Art.269471): same as EMT6-DB, plus short-circuit monitoring

EMT62 (Art.171889): Thermistor protection, 2 sensor circuits, auto reset, 24–240V AC/DC

EMT62-DB (Art.171890): same as EMT62, plus manual/auto reset, remote reset, fault memory.

Electronic Timing Relays, ETR4-series. 22,5mm, Rated operational current 3A, Ith: 6A
ETR4-51-A (Art.031884): Star-delta switching timing functions, Time Range: 3-60s, 24-240V AC/DC

ETR4-51-W (Art.031885): Star-delta switching timing functions, Time Range: 3-60s, 400V AC

ETR4-11-A (Art.031882): On-delayed timing functions, Time Range 0,05s…100h, 24-240V AC/DC

ETR4-11-W (Art.031883): On-delayed timing functions, Time Range 0,05s…100h, 400V AC

ETR4-69-A (Art.031891): Multifunctional timing functions, Time Range 0,05s…100h, 24-240V AC/DC

ETR4-69-W (Art.031887): Multifunctional timing functions, Time Range 0,05s…100h, 400V AC

ETR4-70-A (Art.031888): Multifunctional with connection for potentiometer, two changeover contacts that can be converted to two timed contacts or one non-delayed contact and one timed contact.

Degree of protection: IP20.

Approval conditions
The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Product certificate
If specified in the Rules, ref. Pt.4 Ch.9 Sec.1, the control and monitoring system in which the above listed hardware is used shall be delivered with a product certificate. For each such delivery the certification test is to be performed at the manufacturer of the application system before the system is shipped to the yard. The test shall be done according to an approved test program.

Type Approval documentation

Tests carried out
Applicable tests according to DNV CG-0339, August 2021.

Marking of product
Manufacturer, type designations, electrical ratings, serial number.

Periodical assessment
The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE