



Certificate No:
TAA000034R

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Electrical Control System

with type designation(s)
UNITROL 1005

Issued to

ABB Schweiz AG
Turgi, AG, Switzerland

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Temperature B

Humidity B

Vibration B

EMC A

Enclosure Required protection according to relevant rules shall be provided upon installation on board.

Issued at **Hamburg** on **2022-03-17**

This Certificate is valid until **2026-12-06**.

for **DNV**

DNV local station: **Augsburg**

Approval Engineer: **Jens Dietrich**

.....
Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251

Revision: 2021-03

www.dnv.com

Page 1 of 2

Product description

Compact voltage regulator for synchronous machines UNITROL 1005 (3BHE043576Rxxxx)

Power Supply Input (AC/DC);

AC nominal voltage: 16..250 VAC,

AC voltage max: 300 VAC,

DC nominal voltage (min/max): 25..300 VDC,

DC voltage max: 420 VDC.

Excitation Output – Maximum Ratings: Continuous excitation current at 55 °C: 8 A, at 70°C: 5 A;

Maximum excitation current: 16 A (10s).

2 Analog Inputs (+/-10V, 20mA), 8 Digital Inputs, 0..28V; 2 Isolated Digital Outputs, 2 Non-isolated Digital Outputs

Communication Interfaces: Ethernet 10/100MBit/s.

Application/Limitation

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

The suitability for the respective application generator needs to be checked based on the requirements stipulated in DNV Pt.4 Ch.8 Sec.5.

The Marine Application Notes are to be observed.

Product certificate

If specified in the Rules, ref. Pt.4 Ch.9 Sec.1, the control and monitoring system in which the above listed hardware is used shall be delivered with a product certificate. For each such delivery the certification test is to be performed at the manufacturer of the application system before the system is shipped to the yard. The test shall be done according to an approved test program. After certification the clause for software control will be put into force.

Software control

All changes in software are to be recorded as long as the system is in use on board. Documentation of major changes is to be forwarded to DNV for evaluation and approval before implemented on board. Certification of modified functionality may be required for the particular vessel

Tests carried out

Applicable tests according to DNV-CG-0339, August 2021,

Functional performance test on generator at AEM Dessau.

Marking of product

Manufacturer name, type designation, serial no., electric ratings.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE