



Certificate No:
TAA000035C

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Programmable Electronic System

with type designation(s)
Valmet DNA System, ACN Controller Family

Issued to

Valmet Automation Oy
Espoo, Finland

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Location classes:

Temperature	A
Humidity	B
Vibration	A
EMC	B / A*
Enclosure	Required protection according to relevant rules shall be provided upon installation on board.

Issued at **Høvik** on **2023-01-24**

This Certificate is valid until **2028-01-23**.

DNV local station: **Finland CMC**

for **DNV**

Approval Engineer: **Martin Skårerverket**

.....
Frederik Tore Elter
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251

Revision: 2021-03

www.dnv.com

Page 1 of 3

Product description

Programmable electronic system ACN.

The following units/cards are included in the type approval:

Item	Trade Code	Description
ACN:		
ACN RT G5 DC	D202827	DC Supplied Industrial Process Controller unit, ACN RT
ACN RT G5 AC	D202828	AC Supplied Industrial Process Controller unit, ACN RT
ACN CS G3*	D203409	Compact Industrial Computer, ACN CS G3 with PCIe slots
ACN CSW G3*	D203482	Compact Industrial Computer, ACN CSW G3 with PCIe slots
ACN CS G3 8GB*	VS1002201	Compact Industrial Computer, ACN CS G3 with increased memory
ACN PCI and PCIe cards:		
Moxa CP-114EL-I-DB9M	D202764	Serial controller PCIe Card, 4-port RS-232/422/485
Moxa CP-114UL	D201967	Serial controller PCIe Card, 4-port RS-232/422/485
Intel I210-T1	D202707	Ethernet Server Adapter, Single-Port PCIe
Molex Woodhead SST-PB3-PCIE-1	D202760	PROFIBUS DP Interface PCIe- card, 1-Channel
Adapters:		
UM 45-D	2293666	Phoenix Contact D9 adapter

*For products ACN CS G3, ACN CSW G3 and ACN CS G3 8GB, EMC Location Class A.

Listed products are also available with conformal coating. The trade code of a coated product has a suffix L, e.g., D203409L

Place of manufacture

Valmet Automation Inc.
Tampere, Finland

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Product certificate

If specified in the Rules, ref. Pt.4 Ch.9 Sec.1, the control and monitoring system in which the above listed hardware is used shall be delivered with a product certificate. For each such delivery the certification test is to be performed at the manufacturer of the application system before the system is shipped to the yard. The test shall be done according to an approved test program. After certification the clause for software control will be put into force.

Software control

All changes in software are to be recorded as long as the system is in use on board. Documentation of major changes is to be forwarded to DNV for evaluation and approval before implemented on board. Certification of modified functionality may be required for the particular vessel.

Application/Limitation

For installation on bridge, equipment to be installed not less than 5 m away from magnetic compass.

Ref. IEC 60945 [4.5.3].

Type Approval documentation

Tests carried out

Applicable tests according to class guideline DNV-CG-0339, August 2021.

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE