Certificate No:
TAA000039N

TYPE APPROVAL CERTIFICATE

This is to certify:

That the Peripheral Equipment

with type designation(s)
PSR-M-B2-XC-SDI8-SDO4-DO4-PI

Issued to
Phoenix Contact GmbH & Co. KG
Blomberg, Nordrhein-Westfalen, Germany

is found to comply with
DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.
Location classes:

Temperature	**B**
Humidity	**B**
Vibration	**A**
EMC	**B***
Enclosure	**Required protection according to the Rules shall be provided upon installation on board.**

*** see Application/Limitation**

Issued at **Hamburg** on **2023-04-24**
This Certificate is valid until **2028-04-23**.
DNV local unit: **Essen**

Approval Engineer: **Heinz Scheffler**

for **DNV**

Joannis Papanuskas
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.

Product description

The safety module is used to monitor single or two-channel signal generators and to control actuators.
The safety module safely interrupts circuits.
Configuration carried out with the PSRmodular software.
The inputs are used to connect safe sensors or control devices.
The outputs are controlled after the incoming signals have been evaluated in accordance with the configuration.

Signal connections

- 8 safe digital inputs
- 4 safe digital outputs
- 4 digital signal outputs or 4 reset inputs – configurable
- 4 clock outputs

Achievable safety integrity

- SIL 3 (EN 62061)

Additional features

TBUS interface for connecting safe and non-safe IO modules as well as gateways

- USB 2.0 interface
- Cross circuiting detection
- Optional pluggable screw or Push-in terminal blocks

Application/Limitation

*EMC location class B: In Application the Power Supply QUINT4-PS/1AC/24DC/5 is to be used.

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV Rules for Ships Pt.4 Ch.9 Control and Monitoring Systems.

SIL 3 (EN 62061) is not covered by this certificate and is issued by a notified/recognized Certification Body.

Type Approval documentation

Documents and Test Reports: TAA000039N_Overview_Documents_Rev.00

Tests carried out

Applicable tests according to class guideline DNV-CG-0339, August 2021

Marking of product

Marking of product
The products to be marked with:

- Model name
- Manufacturer name
- Serial number

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer’s product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE