



Certificate no.:
TAA00003CE

TYPE APPROVAL CERTIFICATE

This is to certify:

that the **460 Network Components**

with type designation(s)

Aquam8112-8T-M-L2-L2; Aquam8112-4GE8T-M-L2-L2

issued to

Kyland Technology Co., Ltd.
Beijing, China

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application:

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Location classes:

Temperature D

Humidity B

Vibration B

EMC A

Enclosure Required protection according to the Rules shall be provided upon installation on board.

Issued at **Hamburg** on **2023-11-23**

This Certificate is valid until **2028-11-22**.

for **DNV**

DNV local unit: **Dalian NB & CMC**

Approval Engineer: **Heinz Scheffler**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251

Revision: 2023-09

www.dnv.com

Page 1 of 3

Product description

Managed switches (Layer 2)

Model Aquam8112-PORT-M-PS1-PS2	
Code definition	Code option
Ports-M:	8T = eight 10/100Base-T(X) M12 ports
	4GE8T = four 10/100/1000Base-T(X) M12 ports; eight 10/100Base-T(X) M12 ports
PS1: power input1	L2 (24-36VDC)
PS2: power input2	L2 (24-36VDC)

Firmware Version: Bootloader-R1002

Application/Limitation

Required enclosure protection according to the Rules shall be provided upon installation on board.

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Product certificate

If specified in the Rules, ref. Pt.4 Ch.9 Sec.1, the control and monitoring system in which the above listed hardware is used shall be delivered with a product certificate. For each such delivery the certification test is to be performed at the manufacturer of the application system before the system is shipped to the yard. The test shall be done according to an approved test program. After certification the clause for software control will be put into force.

Software control

All changes in software are to be recorded as long as the system is in use on board. Documentation of major changes is to be forwarded to DNV for evaluation and approval before implemented on board. Certification of modified functionality may be required for the particular vessel.

Type Approval documentation

Test Reports: 2023WT1702-1; 2023WT1702-2

Documents: Hardware Installation Manual Nr. 112023104, Version V1.2; Web Operation Manual Version V1.2

Label information Label Aquam 8112Version V1.0; Block diagram-Aquam8x12 series Version V1.0; AQUAM8112

Software Test Report V1.0, No.: KT/RD Aquam81XX 083

Tests carried out

Applicable tests according to class guideline DNV-CG-0339, August 2021

Marking of product

The products to be marked with:

- Model name
- Manufacturer name
- Serial number
- Hardware / Software version
- Power consumption/ Supply voltage.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE