



Certificate no.:
TAA00003K2

TYPE APPROVAL CERTIFICATE

This is to certify:

that the **Fire Alarm Manual Call Point**

with type designation(s)

JINDOGAE-MCP, BMCP-2000-WT, BMCP-2000-NWT, BMCP-2000-PM

issued to

B-I INDUSTRIAL CO., LTD.

Busan, Korea, Republic of

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application:

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Location classes:

Type	Temperature	Humidity	Vibration	EMC	Enclosure
JINDOGAE-MCP	D	B	A	A	B/IP67
BMCP-2000-WT	B	B	A	A	B/IP44
BMCP-2000-NWT	B	B	A	A	A/IP23
BMCP-2000-PM	B	B	A	A	A/IP23

Issued at **Høvik** on **2025-03-20**

This Certificate is valid until **2030-03-19**.

for **DNV**

DNV local unit: **Busan, CMC Korea**

Approval Engineer: **Frode Nygård**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

JINDOGAE-MCP and BMCP-2000-SERIES are a manual call points used in case of fire.

In the event of a fire, the glass panel at the front of the device can be manually broken. When the glass shatters, it activates the internal switch, transmitting a signal to the receiver.

Specifications:

	JINDOGAE-MCP	BMCP-2000-Series
Type	A Type	A Type
Operating Voltage	17-28 V DC	17-28 V DC
Working Current	400 μ A	360 μ A
Operating temperature	-25°C to +70°C	-25°C to +70°C
Ingress Protection	IP67	IP23(NWT, PM), IP44(WT)

Software version: BMCP-2000 NWT,WT,PM_VER01.hex

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Application/Limitation

Ex-certification is not covered by this certificate. Application in hazardous area to be approved in each case according to Ex-Certification/ Special Condition for Safe Use listed in valid Ex-certificate issued by a notified/recognized Certification Body.

Type Approval documentation

Tests carried out

Applicable tests according to class guideline DNV-CG-0339, August 2021

Performance tests according to EN 54-11:2001+ A1:2005

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

Manufactured by:

B-I INDUSTRIAL CO., LTD

32, Gonghang-ro 767beaonda-gil, Gangseo-gu Busan 46720 Korea

END OF CERTIFICATE