

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Electric Power Cable**with type designation(s)
CJPJ80/SC, CJPJ90/SC

Issued to

**Zhongtian Technology Industrial Wire & Cable System
Co.,Ltd.
Nantong, China**

is found to comply with

**Det Norske Veritas' Rules for Classification of Ships, High Speed & Light Craft and Det Norske
Veritas' Offshore Standards
IEC 60092-353 (2011-08)
IEC 60332-3-22 (2009-02)
IEC 60754-1/2 (2011-11)
IEC 61034-1/2 Ed. 3.1 (2013-06)****Application :****General power and lighting
Flame retardant according to cat. A
Halogen free
Low smoke****Product(s) approved by this certificate is/are accepted for installation on all vessels classed
by DNV GL.**

Type	Voltage class (kV)	Temp. class (°C)
CJPJ80/SC	0,6/1	90
CJPJ90/SC	0,6/1	90

This Certificate is valid until **2019-07-04**.Issued at **Høvik** on **2015-07-05**DNV GL local station: **Shanghai**Approval Engineer: **Georgy Abramenko**for **DNV GL**

**Marit Laumann
Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

Product description

CJPJ80/SC 0,6/1 kV
Conductor Copper wire, class 2 or 5
Insulation HF XLPE
Sheath SHF2
Metal covering Copper wire braid

CJPJ80/SC 0,6/1 kV
Conductor Copper wire, class 2 or 5
Insulation HF XLPE
Sheath SHF2
Metal covering Galvanized steel wire braid

No. of conductors x cross section mm2	No. of conductors x cross section mm2	No. of conductors x cross section mm2	No. of conductors x cross section mm2	No. of conductors x cross section mm2
CJPJ80/SC	CJPJ80/SC	3 x 4	16 x 1	33 x 1,5
1 x 1	CJPJ90/SC	3 x 6	19 x 1	37 x 1,5
1 x 1,5	2 x 1	3 x 10	24 x 1	
1 x 2,5	2 x 1,5	3 x 16	27 x 1	4 x 2,5
1 x 4	2 x 2,5	3 x 25	30 x 1	5 x 2,5
1 x 6	2 x 4	3 x 35	33 x 1	7 x 2,5
1 x 10	2 x 6	3 x 50	37 x 1	10 x 2,5
1 x 16	2 x 10	3 x 70		12 x 2,5
1 x 25	2 x 16	3 x 95	4 x 1,5	14 x 2,5
1 x 35	2 x 25	3 x 120	5 x 1,5	16 x 2,5
1 x 50	2 x 35	3 x 150	7 x 1,5	19 x 2,5
1 x 70	2 x 50	3 x 185	10 x 1,5	24 x 2,5
1 x 95	2 x 70		12 x 1,5	27 x 2,5
1 x 120	2 x 95	4 x 1	14 x 1,5	30 x 2,5
1 x 150	2 x 120	5 x 1	16 x 1,5	33 x 2,5
1 x 185		7 x 1	19 x 1,5	37 x 2,5
1 x 240	3 x 1	10 x 1	24 x 1,5	
1 x 300	3 x 1,5	12 x 1	27 x 1,5	
	3 x 2,5	14 x 1	30 x 1,5	

Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-350	2008-02	General construction and test methods of	

Job Id: **262.1-010228-2**
Certificate No: **TAE0000041**

Standard	Release	General description	Limitation
		power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-353	2011-08	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	0,6/1 kV
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables - Category A	Bunch test Category A
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 60684-2	2011-08	Flexible insulating sleeving – Part 2: Methods of test Clause 45.1 Methods of determination of low levels of chlorine, and/or Bromine and/or iodine Clause 45.2 Methods of determination of low levels of fluorine	HCl + HBr + HJ max 0,5% [0,014% can be detected] HF max 0,1% [0,02% can be detected]
IEC 61034-1/2	2013-06	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke

Marking of product

Zhongtian technology industrial wire and cable systems – CJPJ80/SC or CJPJ90/SC – size – 0,6/1 kV – IEC 60332-3-22

Periodical assessment

The scope of the retention/renewal survey is to verify that the conditions stipulated for the Type approval is complied with and that no alterations are made to the product design or choice of materials. The main elements of the survey are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Production Sample Tests (PST) and Routines (RT) checked (if not available tests according to PST and RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Survey shall be performed at least every second year.

END OF CERTIFICATE