

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Electric Power Cable**with type designation(s)
CJV82/NA, CJV92/NA

Issued to

**Zhongtian Technology Industrial Wire & Cable System
Co.,Ltd.
Nantong, China**

is found to comply with

**Det Norske Veritas' Rules for Classification of Ships, High Speed & Light Craft and Det Norske
Veritas' Offshore Standards
IEC 60092-353 (2011-08)
IEC 60331-1/2 (2009-05)
IEC 60332-3-22 (2009-02)****Application :****General power and lighting****Fire resistant****Flame retardant in bunch acc to cat. A****Product(s) approved by this certificate is/are accepted for installation on all vessels classed
by DNV GL.**

Type	Voltage class (kV)	Temp. class (°C)
CJV82/NA	0,6/1	90
CJV92/NA	0,6/1	90

This Certificate is valid until **2019-07-05**.Issued at **Høvik** on **2015-07-06**DNV GL local station: **Shanghai**Approval Engineer: **Georgy Abramenko**for **DNV GL**

**Marit Laumann
Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

Product description

CJV82/NA 0,6/1kV

Conductor	Copper class 2 or 5
Fire resisting layer	Mica tape
Insulation	HF XLPE
Tape	Non-hygroscopic binder tape
Sheath	PVC
Metallic covering	Copper wire braid
Sheath	PVC

CJV82/NA 0,6/1kV

Conductor	Copper class 2 or 5
Fire resisting layer	Mica tape
Insulation	HF XLPE
Tape	Non-hygroscopic binder tape
Sheath	PVC
Metallic covering	Copper wire braid
Sheath	PVC

No. of cores x Conductor cross section	No. of cores x Conductor cross section	No. of cores x Conductor cross section	No. of cores x Conductor cross section	No. of cores x Conductor cross section
mm2	mm2	mm2	mm2	mm2
1 x 1,0	2 x 1,0	3 x 6	16 x 1,0	30 x 1,5
1 x 1,5	2 x 1,5	3 x 10	19 x 1,0	33 x 1,5
1 x 2,5	2 x 2,5	3 x 16	24 x 1,0	37 x 1,5
1 x 4	2 x 4	3 x 25	27 x 1,0	4 x 2,5
1 x 6	2 x 6	3 x 35	30 x 1,0	5 x 2,5
1 x 10	2 x 10	3 x 50	33 x 1,0	7 x 2,5
1 x 16	2 x 16	3 x 70	37 x 1,0	10 x 2,5
1 x 25	2 x 25	3 x 95	4 x 1,5	12 x 2,5
1 x 35	2 x 35	3 x 120	5 x 1,5	14 x 2,5
1 x 50	2 x 50	3 x 150	7 x 1,5	16 x 2,5
1 x 70	2 x 70	3 x 185	10 x 1,5	19 x 2,5
1 x 95	2 x 95	4 x 1,0	12 x 1,5	24 x 2,5
1 x 120	2 x 120	5 x 1,0	14 x 1,5	27 x 2,5
1 x 150	3 x 1,0	7 x 1,0	16 x 1,5	30 x 2,5
1 x 185	3 x 1,5	10 x 1,0	19 x 1,5	33 x 2,5
1 x 240	3 x 2,5	12 x 1,0	24 x 1,5	37 x 2,5
1 x 300	3 x 4	14 x 1,0	27 x 1,5	

Application/Limitation

Fire resistant according to IEC 60331.

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bundles of Cables or Wires) are fulfilled without any additional measures.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
IEC 60092-350	2008-02	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-353	2011-08	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	0,6/1 kV
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
IEC 60331-1/2	2009-05	Fire resistance / Circuit integrity – Test for method for fire <i>with shock</i> at temperature of at least 830°C for cables rated up to and including 0,6/1 kV	Minimum 90 min
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions - Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables - Category A	SA type cables only: Bunch test Category A

Marking of product

Zhongtian technology industrial cable system co Ltd. – CJPV82/NA or CJV92/NA – IEC 60332-3-22
IEC 60331-1

Periodical assessment

The scope of the retention/renewal survey is to verify that the conditions stipulated for the Type approval is complied with and that no alterations are made to the product design or choice of materials.

The main elements of the survey are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Production Sample Tests (PST) and Routines (RT) checked (if not available tests according to PST and RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Survey shall be performed at least every second year.

END OF CERTIFICATE